Review and Classification of Reliability Indicators for Power Systems with a High Share of Renewable Energy Sources

Evelyn Heylen, Geert Deconinck, Dirk Van Hertem

*KU Leuven, Department of Electrical Engineering, EnergyVille
Kasteelpark Arenberg 10 PB 2445, 3001 Leuven-Heverlee*

Abstract

Power systems with a high share of renewable energy sources face new challenges with respect to reliability management. Scientific literature argues that a paradigm shift is needed in terms of reliability management to efficiently integrate a large amount of renewable energy sources and the required flexibility services. Reliability management involves the use of indicators to support system operation and to assess its performance. Many indicators (proposed to be) used in power system reliability management are presented in technical and scientific literature. To coordinate the development, selection and use of indicators in power systems with a high share of renewable energy sources, this paper presents a structured and consistent overview of the characteristics and the scope of indicators currently in use and available in the literature. A transparent way to characterize indicators is proposed. Available indicators are analyzed in terms of the generic properties of an adequate indicator: relevance in the context of evolving reliability management, ease of use, data availability and reliability determined by the data accuracy. Based on this analysis, missing indicators, shortcomings of existing indicators and directions for future work in a practical and scientific context are identified.

Keywords: Classification; Indicators; Adequacy; Security; Reliability

*Corresponding author

Email address: evelyn.heylen@esat.kuleuven.be (Evelyn Heylen)

1. Introduction

Evolutions in power systems, such as the use of renewable energy sources (RES), have resulted in power systems that are used closer to their limits and are more uncertain. The use of RES, such as wind and solar, has increased significantly during the past decade and is expected to increase further, especially in Europe [1].¹ Wind and solar power generation are highly variable and uncertain in nature and result in more distributed, local generation, compared to the traditional system with large centralized generation plants. Modest penetration levels of wind and solar, up to 20-30%, can be integrated reliably, profitably and affordably according to system operators, but once the inherent flexibility that was built in the grid decades ago is reached, variable RES generation faces integration challenges due to excessive curtailment [1]. The distributed, local generation can also lead to power quality problems, amongst others because conventional, thermal generation that provides frequency control is pushed out of the market, and increased system stress due to bi-directional flows. Therefore, flexibility services are required that should be brought to the market in an appropriate way and result in new stakeholders and existing stakeholders that get new roles.

Continued efforts are required to ensure an adequate reliability level of the power system in modern societies, because electricity demand and society's dependence on electricity are continuously increasing. Currently-used deterministic N-1 reliability management is challenged by the complexity and the many interactions, interdependencies and uncertainties in evolving power systems, e.g., how do we deal with off-shore wind in the N-1 criterion? Do we consider no wind in a neighbouring country as an N-1 contingency state? [3]. Coordi-

¹Under Directive 2009/28/EC, in which renewable energy will have to hold a 20% share in the final European energy demand by 2020, the target for electricity generation is 34.3% of total electricity demand provided by renewable energy sources [2].

nating organizations, such as the North American Electric Reliability Corporation (NERC) and the European Network of Transmission System Operators for Electricity (ENTSO-E), are continuously searching to improve standards for reliability management. Scientific literature argues that a paradigm shift
 30 in terms of reliability management is required to integrate renewable energy sources and smart grid technologies in a cost-effective way [4, 5, 6, 7, 8]. They state that probabilistic reliability management based on economic incentives is better suited to meet the current challenges of power systems [5]. Reliability management consists of reliability assessment and reliability control. Reliability
 35 control aims at taking appropriate decisions to satisfy the reliability criterion. Reliability assessment focuses on answering three questions: (1) What can go wrong?, (2) How often will it happen? and (3) What are the consequences if it happens? [9]. To quantitatively answer the second and the third question, indicators are used. To assure the effectiveness of evolving reliability manage-
 40 ment, the characteristics and scope of available indicators should be reassessed and priorities in indicator development should be specified.

A large literature, both scientific papers and technical reports, is available about indicators and indices (proposed to be) used in power system reliability management. The literature is not coherent and the applied terminology is not
 45 unified, as different terms are used with a similar meaning. More than 15 years ago, Allan and Billinton made a review of existing approaches and measures to evaluate the quality and performance of different power system sectors, such as generation, transmission and distribution. Their discussion of indicators was limited to best practices in probabilistic reliability assessment of systems with
 50 more competition and more stakeholders [10]. A high level of variable and uncertain RES generation was not the major point of concern at that time. Although appropriate indicators are crucial to evaluate and support evolving reliability management, no paper exists to the best of the authors' knowledge that assesses available indicators in power systems with a high share of RES.

55 To coordinate the development, selection and use of indicators in power systems with a high share of renewable energy sources, a structured and consistent

overview of the characteristics and the scope of indicators currently in use and available in the literature is presented. 129 indicators discussed in the scientific literature and in technical reports of system operators and coordinating
60 organizations, such as NERC, ENTSO-E and the Council of European Energy Regulators (CEER), are analyzed. The paper proposes a transparent way to characterize the indicators, which facilitates the assessment of the characteristics, scope and relevance of the available indicators. The relevance, ease of use, data availability and data accuracy of the available indicators are analyzed in
65 the context of evolving reliability management. Based on the executed analysis, missing indicators, potential improvements of existing indicators and directions for future work in a scientific and practical context are revealed.

Section 2 gives a unified definition of the terminology. Section 3 discusses characteristics of indicators, while Section 4 describes different classes of indi-
70 cators and their characteristics. Section 5 gives an overview of indicators of the different classes based on a literature survey. Section 6 discusses the results of the qualitative analysis verifying whether available indicators are adequate in the context of evolving reliability management. Section 7 concludes the paper.

2. Definitions

75 Literature on power system reliability does not make a clear distinction between the terms *measure*, *metric*, *index* and *indicator*. The generic definition of a *measure* is a value quantified against a standard [11], whereas indicators are not related to a standard. Several definitions of the term *indicator* exist. In general, the term *indicator* refers to an observable measure that provides
80 insight into a concept that is difficult to measure directly [12]. According to OECD/DAC², an indicator is “a quantitative or qualitative factor or variable that provides a simple and reliable means to measure achievement or to reflect changes connected to an intervention” [13]. According to the definition adopted

²OECD/DAC: Organisation for Economic Co-operation and Development/Development Assistance Committee

by USAID³, an indicator is “a quantitative or qualitative variable that provides
85 reliable means to measure a particular phenomenon or attribute” [14]. However,
in the strictest sense, an indicator does not measure. An indicator can be
considered as an indication of a measure.

An *index* is defined as a combination of related indicators that intend to
provide means for meaningful and systematic comparisons of performance across
90 programs that are similar in content and/or have the same goals and objectives
[15]. It is a scaled composite statistic that aggregates multiple indicators to
capture some property in a single number and rank and summarize observations
[16, 17].

Metrics put a variable in relation to one or more other dimensions [11]. A
95 *metric* is often used as a general term to describe the method used to mea-
sure something, i.e., the resulting values obtained from measuring, as well as a
calculated or combined set of indices [18].

Table 1 summarizes the definitions.

Table 1: Summary of the terminology.

Term	Definition
Measure	Value quantified according to standard
Indicator	Quantitative or qualitative indication of achievement
Index	Composite statistic based on measures and indicators making it possible to rank and summarize observations
Metric	Set of measures, indicators or indices to evaluate a certain property

3. Characteristics of indicators

100 Indicators and indices (proposed to be) used in power system reliability
management have a multitude of characteristics. This section presents a unified

³USAID: United States Agency for International Development

characterization of indicators that facilitates the assessment of similarities and differences between indicators and enables their classification. The characterization is determined by the indicator type, the assessment method to evaluate
105 the indicator value and the type of the indicator value.

3.1. Types of indicators

Endrenyi distinguished four types of indicators to assess system malfunctioning in a power system reliability context: probabilities, i.e., what is the chance that the system is malfunctioning, frequencies, i.e., how often does the system
110 malfunction, mean durations, i.e., how long lasts the system malfunctioning on average, and expectations of malfunctioning [19]. Replacing *expectations* by *magnitude* results in a more generic characterization. The magnitude of malfunctioning corresponds to the degree of violation of the boundary of acceptable behavior or the magnitude of the consequences of malfunctioning. To determine
115 the proper functioning of a component or system, a definition of satisfactory behavior is required. Based on this definition, the performance of the system can be determined. Risk is an additional type of indicator, which is particularly of interest in the context of increasing uncertainties in power systems. Risk indicators take into account the probability and severity, i.e., the magnitude of
120 the consequence, of malfunctioning. These different types of indicators can be further subdivided.

3.1.1. Hierarchical levels

The hierarchical levels determine the facilities or system on which the indicator is focusing. Traditionally, three hierarchical levels have been distinguished.
125 Hierarchical level I (HLI) focuses on the generation facilities in classical power system reliability literature, whereas hierarchical level II (HLII) considers both the generation and transmission facilities. Hierarchical level III (HLIII) covers the combination of generation, transmission and distribution facilities [20].⁴ Indicators can be specific for a particular level or can be used at multiple levels.

⁴HLIII studies in practice mainly focus on the distribution level to reduce the problem size.

130 Due to the increased penetration of RES distributed over the system, the strict distinction between the three hierarchical levels has diminished.

3.1.2. Measures

The main objective of power system reliability management is to obtain a low frequency of inability to serve load with the required quality and a very low
135 frequency of experiencing spectacular system failures, such as blackouts [20]. To achieve this objective, physical measures, such as voltage, frequency, loading of components and current, should be within limits. Besides respecting the physical limits of the system, cost-effectiveness of reliability management becomes more important. The assessment of cost-effectiveness requires the monitoring
140 of monetary measures.

3.1.3. Type of the interruption

Indicators can be differentiated based on the type of the interruption. HLIII indicators make a distinction between types of interruptions based on their duration by defining indicators for sustained interruptions and short or momentary
145 interruptions [21]. Moreover, indicators can differ for planned and unplanned interruptions. This difference is related to the advance notification of consumers [22]. The cost of energy not supplied (CENS) regulation in Norway additionally differentiates the indicators depending on the time of occurrence of the interruption [22].

150 3.1.4. Scope of the indicators

Allan and Billinton define system indicators and load-point indicators [10]. They define system indicators as global indicators representing the behavior of the overall system. Load-point indicators on the contrary focus at individual bulk supply points. They evaluate the impact of a certain reliability decision
155 on a particular bulk supply point. Allan and Billinton explicitly mention the complementarity of system and load-point indicators.

Alternative terms to denote the scope of an indicator are zonal and local indicators. Zonal indicators operate system wide, local indicators by contrast

focus on a smaller part of the system, such as a component⁵, a node or a supply
point. Zonal indicators complemented with the local values provide an overall
160 picture of system behavior [24].

The terminology zonal/local indicators is more generic than system/load-
point indicators. It is better suited to apply in systems with more stakeholders
and stakeholders with different roles, because local indicators are not restricted
165 to load points.

3.1.5. *End-user- and system-related indicators*

Different indicators are used if different entities are studied, i.e., the end-
users or the system itself. End-user-related and system-related indicators can
be distinguished. End-user-related indicators focus on the impact of an event
170 on one or more end-users. Local end-user-related indicators represent the per-
formance of a particular end-user or end-users of a load point or region, whereas
zonal end-user-related indicators consider all end-users in the system. System-
related indicators on the contrary quantify system-related concepts, such as
voltage, current and frequency. Local system-related indicators focus on parts
175 of the system, e.g., a single component or node in the system, whereas zonal
system-related indicators look at the overall system.

3.1.6. *Mono-, bi- and multi-parametric indicators*

Indicators can be characterized based on the number of statistical parameters
they express. Mono-parametric indicators employ a single statistical parameter,
180 whereas bi-parametric indicators are expressed by two statistical parameters
[25]. A frequency and duration indicator for instance gives information on the
average rate a specific state is encountered and the average residence time in
a specific state [25]. Moreover, multi-parametric indicators exist that express
more than two statistical parameters, .

⁵A component is a device which performs a major operating function and which is regarded
as an entity for purposes of recording and analyzing data on outage occurrences, such as a
transformer, series capacitors or reactors etc. [23].

185 *3.1.7. Leading and lagging indicators*

Leading and lagging indicators differ in the moment that they are evaluated. Lagging indicators are result-oriented, measure historical events and tend to be easier to interpret than leading indicators, which precede events. The objective of leading indicators is to recognize and eliminate unreliable actions and at-risk conditions [26]. Leading indicators tend to change before an activity and, as a
190 consequence, can be used as a predictor. They gain importance in power systems with increasing uncertainty. Leading indicators are also denoted as pro-active indicators [12]. Ex-ante and ex-post indicators are other terms for resp. leading and lagging indicators.

195 *3.1.8. Deterministic and probabilistic indicators*

Indicators can be deterministic or probabilistic in nature. Deterministic indicators consider a single system state, whereas probabilistic indicators consider a prescribed set of system states with their respective probability. Ex-post or lagging indicators are deterministic, whereas leading or ex-ante indicators can
200 be deterministic or probabilistic.

Most deterministic indicators are lagging indicators used to measure the historical performance of the power system. Some leading deterministic indicators exist as well, which can be used as an indication for the future performance of the system.

205 Probabilistic indicators are typically expectations, i.e., the average of a probability distribution [27], which are used ex-ante to estimate the system's performance [28]. They capture uncertainty more adequately than deterministic indicators as both the severity and probability of events can be considered. This makes them especially useful in power systems with increasing uncertainties.

210 *3.1.9. Activity and outcome indicators*

Activity and outcome indicators look at the actions taken in system operation and their consequences. Activity indicators give information on the level of targeted activities to improve reliability, whereas outcome indicators measure

whether the targeted activity has led to an improved reliability level [12].

215 3.2. Type of assessment

Indicator values are the result of a short-term or long-term reliability assessment. A short-term reliability assessment can be dynamic, pseudo-dynamic or static and typically spans seconds up to hours [29, 30]. It typically focuses on the composite generation and transmission level (HLII). A long-term reliability assessment is more high level and focusses on the generation level (HLI),
220 the composite generation and transmission level (HLII) or the distribution level (HLIII). A long-term assessment is typically static in nature and can span years up to decades.

3.3. Types of indicator values

225 The focus of the assessment and the risk aversion of the decision maker determines the type of the indicator value that is of interest. Types of indicator values are maximal or minimal values, average/mean values, expected values, probability density functions, instantaneous values, value at risk, conditional value at risk, etc. Also the period over which the indicator is evaluated can
230 differ, distinguishing annual, monthly, daily, hourly or instantaneous indicators or indicators focussing on a particular period in the year, the worst period for instance [21]. Moreover, a distinction can be made between annual and annualized indicators [24]. The type of the indicator value that can be obtained and the type of the assessment that is applied are interrelated.

235 4. Classification of indicators and their characteristics

Power system reliability is defined as the ability of an electric power system to perform a required function under given conditions for a given time interval [31]. It quantifies the ability of a power system to provide an adequate supply of electrical energy satisfying the consumer requirements with few interruptions
240 over an extended period of time. Power system reliability consists of *power system adequacy* and *power system security* [32]. An adequate power system

has sufficient generation, transmission and distribution facilities to satisfy the aggregate electric power and energy requirements of consumers at all times, taking into account scheduled and unscheduled outages of system components [20].⁶ System security on the contrary describes the ability of the system to handle disturbances, such as the loss of major generation units or transmission facilities [20]. Power system security and adequacy are however interdependent, since adequacy is subject to transitions between different states, which are in the strict sense no part of the adequacy analysis, but of the security analysis [10]. Adequacy and security of a power system are interlinked with its coping capacity. The *coping capacity* represents the ability of the operator and the power system itself to cope with an unwanted event, limit negative effects and restore the power system's function to a normal state [34]. The coping capacity of the power system together with its *susceptibility* determine the power system's vulnerability to external threats that can lead to failure modes. If a realized threat leads to an unwanted event in the power system, it is susceptible to this threat. The increasing uncertainty in power systems due to a high share of RES increases the potential threats the system is facing, e.g., due to forecast errors and variability of RES generation. The power system's *vulnerability* is an expression of the problem the system faces to maintain its function if a threat leads to an unwanted event and the difficulties to resume its activities after the event occurred [34]. Vulnerability is an inherent characteristic of the system and depends on the working force of the system operator, its organizational structure and the technical aspects of the system, such as the availability of the components, which is determined by their reliability and maintainability [35].⁷ The reliability of the system is determined by its vulnerability, the threats it is facing and the reliability criterion that is applied. The interlinking between the

⁶The North American Reliability corporation (NERC) denotes security as operational reliability [33].

⁷Maintainability is defined as the probability of performing a successful repair action within a given time [31].

aspects determining the system's reliability level are indicated in Fig. 1.

Figure 1: Interaction between different aspects determining reliability of power systems

Literature typically distinguishes adequacy, security and reliability indicators. Moreover, socio-economic indicators gain importance in more advanced, probabilistic reliability management approaches and criteria based on economic principles [36]. Besides these classes of indicators, Hofmann et al. [35] formulate high level indicators for monitoring vulnerability. They make a distinction between indices for coping capacity, criticality, threats and susceptibility. Indicators for threats and susceptibility are divided in classes: natural hazard, human threats and operational conditions.

This section discusses the four main classes of indicators: adequacy, security, socio-economic and reliability indicators. We attribute characteristics to each of the classes to facilitate the classification and characterization of indicators available in literature.

4.1. Adequacy indicators

Adequacy indicators represent the ability of an electric power system to supply the aggregate electric power and energy required by the consumers, under steady-state conditions, with system component current ratings not exceeded, bus voltages and system frequency maintained within tolerances, taking into account planned and unplanned system component outages [31]. Adequacy indicators focus on the end-users rather than the system or individual components. They are the result of a steady-state assessment and are physical rather than

socio-economic in nature. Adequacy indicators exist for the three hierarchical
 290 levels, i.e., generation (HLI), composite generation and transmission (HLII) and
 composite generation, transmission and distribution (HLIII) [25, 10]. Adequacy
 indicators can be lagging and deterministic or leading and probabilistic out-
 come indicators. The indicators are of four types, i.e. magnitude, probability,
 frequency and duration.

295 4.2. Security indicators

Security indicators show the ability of the system to operate in such a way
 that credible events do not give rise to loss of load, operation of system compo-
 nents beyond their ratings, bus voltages or system frequency outside tolerances,
 instability, voltage collapse or cascading [31]. Security indicators focus on the
 300 composite generation and transmission system (HLII). They are rather system-
 than end-user-related. Security indicators can be deterministic, leading or lag-
 ging or probabilistic, leading outcome indicators. They can be of all five types,
 i.e., risk, magnitude, probability, frequency and duration. Risk-based security
 indicators are especially suitable in a context of increasing RES penetration.

305 The evaluation of security indicators involves a dynamic, pseudo-dynamic
 or steady-state security assessment, depending whether transients after the dis-
 turbance are neglected or not [37]. Steady-state security can be considered as
 a first-order approximation of the dynamic power system state [29]. Alterna-
 tively, pseudo-dynamic evaluation techniques exist that use sequential steady-
 310 state evaluations to assess the impact at several post-contingency stages [30].
 Based on the indicators resulting from the security assessment, system opera-
 tors verify the compliance with the security limits and determine the magnitude
 of security limit violations.

4.3. Socio-economic indicators

315 Alternative reliability management approaches and criteria based on eco-
 nomic principles incorporate socio-economic indicators in their decision making
 [7, 38]. Socio-economic indicators cover all types of costs, benefits or surpluses

of individual power system stakeholders or an aggregated system. Power system stakeholders currently impacted by power system reliability are electricity generators, system operators, end-consumers, the government and the environment, all facing different types of costs and benefits. Given the challenges power systems with a large share of RES are facing, additional stakeholders, such as flexibility providers, might be integrated in the system or existing stakeholders might get new roles.

Table 2 gives a high-level representation of socio-economic interactions between consumers, producers and system operators. Each of these stakeholders has its own balance, while the interactions between them result in an overall system balance. The upper and lower part of the table make a distinction between respectively system costs and cost transfers. System costs and benefits have resp. a negative and positive effect on socio-economic surplus, which is defined as the sum of surplus or utility of all stakeholders, including external costs and benefits (e.g., environmental costs), over the expected operating range [39]. Cost transfers on the contrary appear as costs to a certain stakeholder, while being a payment, and thus benefit, to another stakeholder. They do not affect the socio-economic surplus.

Socio-economic indicators can be deterministic or probabilistic. Both socio-economic activity and outcome indicators exist. Socio-economic indicators mainly represent a risk or a magnitude and can focus on the system, the end-user or both. Socio-economic indicators are evaluated using a long-term or a short-term assessment.

4.4. Reliability indices

The definition of reliability indices differs between different sources. In [31], reliability indices are defined as a measure of the probability that an item or system can perform as required, without failure, for a given time interval⁸, under

⁸The time interval duration may be expressed in units appropriate to the item concerned, e.g. calendar time, operating cycles, distance run, etc., and the units should always be clearly

Table 2: Overview of cost and benefits of, and socio-economic interactions between, power system stakeholders resulting in an overall system balance [39]

	Stakeholders' balances			System balance
	Consumer balance	Producer balance	System operator (SO) balance	
System costs	+ Consumer benefits - Interruption costs	- Variable costs - Fixed costs	- Variable costs - Fixed costs	+ Consumer benefits - Interruption costs - Variable producer costs - Fixed producer costs - Variable SO costs - Fixed SO costs
Cost transfers	+ Interruption compensation + Demand response payment - Transmission tariff - Electricity payment	+ Electricity payment - Capacity fee + Reserve payment + Congestion payment	- Interruption compensation - Demand response payment + Transmission tariff + Capacity fee - Reserve payment - Congestion payment	

345 given conditions.⁹ According to [31], reliability indices are restricted to mean durations, frequencies and probabilities.

NERC defines reliability as "an electricity service level or the degree of performance of the bulk power system defined by accepted standards and other public criteria". Reliability indices are thus also denoted as reliability performance indices. A reliability performance index summarizes the reliability performance with regards to the reliability criterion and reliability standards. The reliability performance depends on the one hand on how the system is loaded in comparison to its limits and the reliability standards and on the other hand on the reliability of each of its individual components. Therefore, reliability indices can be determined on system or component level. Moreover, they can consider the end-users and/or the overall system. Instead of monitoring a set of reliability performance indices, integrated indices represent all hierarchical levels and combine the adequacy, security and socio-economic indicators determining the reliability standards with appropriate weighting factors.

360 4.5. Summary

A summary of the general characteristics of the classes of indicators is given in Table 3. The four classes contain deterministic and probabilistic indicators and incorporate local and zonal indicators.

The distinction between adequacy indicators focusing on the composite generation and transmission system and security indicators resulting from a steady-state analysis and focusing on loss of load is not that clear from their definition. This distinction depends on the type of assessment. Some of the indicators denoted in literature as security indicators can also be classified as HLII adequacy indicators. This is indicated by (x) in Table 3. Multiple 'x' in the same section of Table 3 indicate that different indicators of that class have different characteristics related to that section. It does not mean that all characteristics need

stated [31].

⁹Given conditions include aspects that affect reliability, such as mode of operation, environmental conditions and maintenance, where applicable [31].

to be present at the same time.

Table 3: Characteristics of different classes of indicators

Indicators	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Adequacy	o	x	x	o	o	x	x	x	x
Security	x	o	x	o	x	(x)	o	x	o
Socio-economic	x	x	o	x	x	x	o	x	x
Reliability	x	x	x	x	x	x	x	x	x

(1) Short term, (2) Long term, (3) Physical, (4) Socio-economic, (5) System, (6) End-user,
(7) HLI, (8) HLII, (9) HLIII

o = not applicable, x = can be applicable

5. Overview and classification of indicators

A multitude of indicators and indices is presented and described in literature,
ranging from indicators and indices used in a practical context to more theoret-
ical indicators and indices that are suggested for future reliability management.
This section gives an overview of practical indicators and indices prescribed by
ENTSO-E and NERC or discussed by the CEER, as well as theoretical indica-
tors and indices discussed in scientific literature. The indicators and indices are
assessed based on the characteristics discussed in Section 3 and are assigned to
the classes discussed in Section 4.

5.1. Adequacy indicators

NERC prescribes to evaluate HLI resource adequacy probabilistically based
upon reserve margin projections and emerging risks that have been identified
in a long-term reliability assessment. The long-term reliability assessment is a
peak-driven, deterministic approach to gage resource adequacy. Complementary
to the deterministic approach, NERC defines five probabilistic adequacy indices
in their guidelines [40, 41].

- Expected unserved energy (EUE): A measure of the resource availability
to continuously serve all loads at all delivery points while satisfying all

planning criteria [MWh]. The expected amount of energy not supplied by the generating system during the period of observation, due to capacity deficiency [42].

- Loss-of-load hours (LOLH): The expected number of hours per year when a system's hourly demand is projected to exceed the generating capacity.
- Loss-of-load expectation¹⁰ (LOLE): The expected number of days per year for which the available generation capacity is insufficient to serve the daily peak demand.
- Loss-of-load probability (LOLP): The probability of system daily peak or hourly demand exceeding the available generating capacity during a given period.
- Loss-of-load events (LOLEV): The number of events in which some system load is not served in a given year.

To verify the HLII adequacy and security, NERC defines an Adequate Level of Reliability (ALR) in terms of reliability standards [33].¹¹ The objective is to obtain standards that balance the cost of risk mitigation and the cost of risk itself. To verify the reliability standards and to provide feedback for improving them, system performance metrics are defined.¹² Part of NERC's indicators in the system performance metric to verify the adequate level of reliability are adequacy oriented:

- ALR1-3: Planning reserve margin.

¹⁰Sometimes also denoted as Loss of Load Expectancy.

¹¹NERC's definition of Adequate Level of Reliability is continuously updated. The most recent information can be found at <https://www.nerc.com/comm/Other/Pages/Adequate%20Level%20of%20Reliability%20Task%20Force%20ALRTF.aspx> [accessed 16 August 2018].

¹²A more detailed definition and description of each of the different ALR indices can be found at [https://www.nerc.com/comm/PC/Pages/Performance%20Analysis%20Subcommittee%20\(PAS\)/Approved-Metrics.aspx](https://www.nerc.com/comm/PC/Pages/Performance%20Analysis%20Subcommittee%20(PAS)/Approved-Metrics.aspx) [Accessed 16 August 2018]

- ALR6-2: Energy emergency alert 3 (firm load interruptions due to capacity and energy deficiencies).
- ALR6-3: Energy emergency alert 2 (deficient capacity and energy during peak load periods).

415

The other indicators are mainly system security oriented.

ENTSO-E's approach for system adequacy assessment was initially deterministic. It was based on the point with the highest load. Due to the increasing penetration of RES and the increasing uncertainty that comes with it, a gradual movement towards a probabilistic approach is initiated with ENTSO-E's target methodology for adequacy assessment [43]. This methodology proposes to use a set of 5 indicators in a generation adequacy assessment. Besides LOLE and LOLP, which are also proposed by NERC, these indicators are:

420

- Full load hours of generation: The time needed to produce the total energy under full load conditions of the generators, which represents the utilization rate of the generation park.
- RES curtailment: Amount of energy from renewable energy sources that cannot be produced due to security reasons.
- CO₂ emissions: Amount of CO₂ emissions.

425

430 Loss of load probability (LOLP), loss of load expectancy (LOLE)¹³ and
 expected unserved energy (EUE)¹⁴ are frequently used for adequacy assessment
 in practice. They are suggested by NERC and also used in Belgium, Finland,
 France, Great Britain, Hungary, Ireland and the Netherlands in a probabilistic
 assessment to verify generation adequacy. Also in scientific literature, these
 435 indicators are suggested [10, 45]. Newell et al. propose to use normalized
 expected unserved energy (EUE) for setting the resource adequacy standard,
 because it is a more robust and meaningful measure of reliability that can be
 compared across systems of many sizes, load shapes and uncertainty factors
 [46]. In Spain and Sweden, generation adequacy is verified in terms of the
 440 capacity margin, which is a deterministic indicator [21, 47].¹⁵ This is a very
 simple indicator, but not appropriate in systems with a significant amount of
 intermittent generation [27].

¹³The definition of LOLE differs between sources. NERC defines LOLE as the expected
 number of days per year with a deficiency calculated based on the peak load per day or a
 load curve [40]. In Europe, LOLE is defined as the expected number of hours per year during
 which it will not be possible for all the generation resources available to the system to cover the
 load, even taking into account the interconnections [27]. The latter is equivalent to the LOLH
 defined by NERC or can also have the notion of an hourly LOLE. A frequently used LOLE
 threshold is the industry-accepted reliability standard of 1 day in 10 years or 0.1 days/year
 [44]. It is important to notice that this does not corresponds to a LOLH of 2.4h/year, because
 the LOLH corresponding to a LOLE of 0.1 days/year can be significantly higher.

¹⁴Sometimes also denoted as loss of energy expectation (LOEE) or expected energy not
 supplied/served (EENS) in a generation adequacy context, which have the same definition
 [10]. A slight difference with EENS is that EENS is not only used in a generation adequacy
 context, but is also applied on the HLII and HLIII level. The distinction depends on the
 primary cause of the interruption, which can be lack of power (HLI), lack of interconnection
 (HLI and HLII), line overload (HLII) or network splitting or isolated nodes (HLII). A drawback
 of EENS is that it cannot be used to compare different systems. This requires a normalization
 [27].

¹⁵Capacity margin is defined as the proportion by which the total expected available gener-
 ation exceeds the maximum expected level of electricity demand, at the time at which that
 demand occurs [48].

Adequacy assessment of the transmission system (HLII) is the responsibility of the individual countries in Europe [27]. Indicators used by system operators
445 to assess the adequacy of their generation and transmission systems are [27, 45]:

- Expected energy not supplied (EENS): The expected total summated energy not supplied to any of the load buses irrespective of the cause and the location of the deficiency.
- Energy index of unreliability (EIU): EENS normalized by the total energy
450 demanded.
- Energy index of reliability (EIR): $EIR = 1 - EIU$.
- System minutes: EENS normalized by peak demand representing equivalent minutes of unavailability.
- $LOLE_{P95}$: The number of hours during which load cannot be covered by
455 all available means in a very cold winter, i.e., a critical scenario.
- Average interruption time (AIT): A measure for the amount of time the supply is interrupted, expressed as the total number of minutes that the power supply is interrupted during the year [27].

A set of other local and zonal indices that can be used in composite generation
460 and transmission system evaluation (HLII) is proposed in [10] and [45].

Adequacy indicators that can be used on HLIII are discussed by Allan and Billinton [10]. Moreover, an IEEE standard is created focussing on distribution adequacy indicators [49]. Although these indicators are referred to as reliability indices in [49], their main focus is on adequacy aspects. Most commonly-used
465 adequacy indicators on the distribution level (HLIII) in Europe are SAIFI and SAIDI¹⁶ [50].

¹⁶SAIFI stands for System Average Interruption Frequency Index, which represents the number of consumer interruptions divided by the number of consumers served, while SAIDI stands for System Average Interruption Duration Index and represents the sum of consumer-sustained outage minutes per year divided by the number of consumers served [27].

470 An overview and characterization of the different adequacy indicators is given in Table 4. Existing literature makes a clear distinction between the different hierarchical levels. However, due to the increasing amount of distributed generation, the distinction is blurred in practice and composite evaluations are more important.

Table 4: Characterization of adequacy indicators

Indicators	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	Reference
LOEE										[10]
EENS										[10]
EIR	x	o	o	o	o	x	x	o	o	[10]
EIU										[10]
System minutes										[10]
EUE										NERC, [10, 46, 47]
LOLH										NERC, [10]
Loss of load duration (LOLD)	o	o	o	x	o	x	x	o	o	[51]
Maximum load curtailed										[10]
Maximum energy curtailed										[10]
Average load curtailed/curtailment										[10]
Average energy not supplied/curtailment	x	o	o	o	x	o	o	x	o	[10]
Average load curtailed/load point										[10]
Average energy curtailed/load point										[10]
Maximum system load curtailed under any contingency condition										[10]
Maximum system energy not supplied under any contingency condition										[10]
Expected load curtailed										[10]
Expected demand not supplied										[51]
EENS	x	o	o	o	o	x	o	x	o	[10]

Modified bulk power en- ergy curtailment index										[51]
System minutes										[10]
Bulk power interruption index										[51]
Bulk power supply aver- age MW curtail- ment/disturbance	x	o	o	o	x	o	o	x	o	[51]
Bulk power energy curtail- ment index										[51]
ALR1-3										NERC
System average interruption frequency index (SAIFI)										[10, 49, 50, 52]
Customer average interruption duration index (CAIFI)	o	o	x	o	x	o	o	o	x	[10, 49, 50, 52]
Momentary average interruption frequency index (MAIFI)										[49, 50]
Momentary average interruption event frequency index (MAIFI _E)										[49]
Average system interruption frequency index (ASIFI)										[49, 50]
Transformer SAIFI										[50]
Equivalent number of interruptions related to the installed capacity (NIEPI)										[50]
System average interruption duration index (SAIDI)										[10, 49, 50, 52]
Customer average interruption duration index (CAIDI)	o	o	o	x	x	o	o	o	x	[10, 49, 50, 52]
Outage duration at individ- ual load point										[10]
Customer total average interruption duration index (CTAIDI)										[49, 50]
Average system interruption duration index (ASIDI)										[49, 50]
Full load hours of generation										ENTSO-E

RES Curtailment					ENTSO-E					
CO ₂ Emissions					ENTSO-E					
Generation reserve margin					[21]					
Percent reserve evaluation					[21]					
Loss of the largest generating unit					[21]					
Average service availability index (ASAI)					[10, 49, 52]					
Customers experiencing multiple interruptions (CEMI _n)	o	x	o	o	x	o	o	x	[49]	
Customer experiencing longest interruption durations (CELID)									[49]	
Customers experiencing multiple sustained interruption and momentary interruption events (CEMSMI _n)									[49]	
Customers experiencing multiple momentary interruptions (CEMMI _n)									[27]	
Average Energy not Served (AENS)	x	o	o	o	x	o	o	x	[10]	
Energy not distributed (END)									[50]	
EENS	x	o	o	o	o	x	o	o	x	[10]
Transformer SAIDI									[50]	
Equivalent interruption time related to the installed capacity (TIEPI)	o	o	o	x	x	o	o	x	[50]	
Customer minutes lost (CML)									[50]	
Average interruption time (AIT)									[50]	
Average interruption duration (AID)	o	o	o	x	x	o	o	x	o	[50]
Average duration of load curtailed/load point									[10]	

System average restoration index (SARI)										[50]
Average number of curtailments/load point										[10]
Average interruption frequency (AIF)	o	o	x	o	x	o	o	x	o	[50]
ALR6-2										NERC
ALR6-3										NERC
Probability of load curtailment	o	x	o	o	o	x	o	x	o	[51]
Expected duration of load curtailment	o	o	o	x	o	x	o	x	o	[10]
Expected duration of load curtailment (local)										[51]
Expected frequency of failure	o	o	x	o	o	x	o	x	o	[10]
Expected number of curtailments (local)										[10]
Maximum duration of load curtailment	o	o	o	x	x	o	o	x	o	[10]
Average duration of curtailment/curtailment										[51]
Failure rate at ind. load point	o	o	x	o	o	x	o	o	x	[10]
Unavailability at ind. load point	o	x	o	o	o	x	o	o	x	[10]
LOLEV										NERC
LOLF	o	o	x	o	o	x	x	o	o	[51]
LOLE										NERC, ENTSO-E, [10, 47]
LOLE _{P95}										[27]
LOLP	o	x	o	o	o	x	x	o	o	NERC, ENTSO-E, [10, 47, 53]

(1) Magnitude, (2) Probability, (3) Frequency, (4) Duration, (5) Deterministic, (6) Probabilistic, (7) HLI, (8) HLII, (9) HLIII
o = not applicable, x = applicable

475 5.2. Security indicators

Besides the adequacy-related standards of the adequate level of reliability discussed in the previous subsection, NERC has defined some security-related

indicators to verify security-related standards of the adequate level of reliability [33].¹²

- 480 • ALR1-4: Bulk power system transmission-related events resulting in loss of load;
- ALR1-5: Transmission system voltage profile;
- ALR1-12: Interconnection frequency response;
- ALR2-3: Activation of underfrequency load shedding;
- 485 • ALR2-4: Average percent non-recovery disturbance control standard events;
- ALR2-5: Disturbance control events greater than most severe single contingency;
- ALR3-5: Interconnected reliability operating limit/system operating limit exceedances;
- 490 • ALR4-1: Automatic transmission outages caused by failed protection system equipment;
- ALR6-1: Transmission constraint mitigation;
- ALR6-11: Automatic AC transmission outage initiated by failed protection system equipment;
- 495 • ALR6-12: Automatic AC transmission outages initiated by human error.

In 2013, ENTSO-E published the second version of the network code on operational security, which prescribes that European transmission system operators should monitor deterministic security indicators based on a state classification. According to this network code, the TSO shall classify the system state based on 5 well-defined categories: normal, alert, emergency, in-extremis and restoration. 500 Dy Liacco presented the three-state security-state diagram in 1967 [54] and an extended five-state version was proposed by Fink and Carlsen in 1978 [55].

Billinton and Khan proposed in 1992 to calculate frequency and probability of being in a particular state as security indicators [56].

505 In 2015, ENTSO-E started merging the three operational network codes (operational planning and scheduling, operational security and load frequency control and reserve) in a single system operation guideline. This guideline prescribes that in operational planning five indicators should be calculated to count the number of events due to a certain cause that resulted in a degradation of
510 system operation conditions [57]:

- OPS 1A: The number of events per year that result in a degradation of system operation conditions due to an incident on the contingency list;
- OPS 1B: The number of events in OPS 1A caused by an unexpected discrepancy of demand or generation forecasts;
- 515 • OPS 2A: The number of events per year that result in a degradation of system operation conditions due to out-of-range contingencies;
- OPS 2B: The number of events in OPS 2A caused by an unexpected discrepancy of demand or generation forecasts;
- OPS 3: The number of events per year that result in a degradation of
520 system operation conditions due to lack of active power reserves.

OPS 1B and OPS 2B focus on the impact of uncertainty due to RES and load, which becomes more important in modern power systems.

Besides the indicators for operational planning, a multitude of performance indicators should be reported annually in the context of operational security
525 [57]. This set of indicators consists of indicators representing the frequency of an event, as well as indicators representing the duration and/or magnitude of events:

- RT1: Number of tripped transmission system elements per year per TSO;
- RT2: Number of tripped power generation facilities per year per TSO;

- 530 • RT3: Energy not supplied per year due to unscheduled disconnection of demand facilities per TSO;
- RT4: Time duration and number of instances of being in the alert and emergency states per TSO;
- RT5: Time duration and number of events within which there was a lack
535 of reserves identified per TSO;
- RT6: Time duration and number of voltage deviations exceeding the voltage ranges specified in [57];
- RT7: Number of minutes outside the standard frequency range and number of minutes outside the 50% of maximum steady-state frequency deviation
540 per synchronous area;
- RT8: Number of system-split separations or local blackout states;
- RT9: Number of blackouts involving two or more TSOs.

RT4, RT5 and RT6 are bi-parametric rather than mono-parametric indices, as they include both the duration and frequency of the event.

545 Ni et al., Ciapessoni et al. and Dissanayaka et al. proposed some probabilistic security indicators, such as low voltage risk indicator, overload risk indicator, voltage instability risk indicator, cascading risk indicator, overloading risk indicator, high current risk indicator and transient stability risk indicator [4, 58, 59]. These risk indicators combine the magnitude and the probability
550 of a security limit violation. Kirschen et al. have developed a probabilistic indicator of system stress that can be used complementary to the N-1 approach in power system operation. This probabilistic indicator is based on expected energy not served (EENS). It is a probabilistic, leading indicator that allows operators to implement preventive measures and plan corrective measures taking
555 into account probabilities and consequences of contingencies [60].

An overview of the security indicators is given in Table 5. To evaluate the security indicators, busbar voltages, active power flows, reactive power flows

and frequency should be monitored [57].

Table 5: Characterization of security indicators

Indicators	(1)	(2)	(3)	(4)	(5)	(6)	(7)	Reference
Low voltage risk indicator								[4]
Voltage instability risk indicator								[4]
Cascading risk indicator	x	o	o	o	o	o	x	[4]
Overloading risk indicator								[4]
High current risk indicator								[58]
Transient stability risk indicator								[59]
Loss of load risk indicator								[58]
Expected energy not served								[60]
ALR1-12								NERC
ALR6-1	o	x	o	o	o	x	o	NERC
RT3								ENTSO-E
ALR1-4								NERC
ALR2-3								NERC
ALR2-4								NERC
ALR2-5								NERC
ALR3-5								NERC
ALR4-1								NERC
ALR6-11								NERC
ALR6-12								NERC
OPS1A	o	o	o	x	o	x	o	ENTSO-E
OPS1B								ENTSO-E
OPS2A								ENTSO-E
OPS2B								ENTSO-E
OPS3								ENTSO-E
RT1								ENTSO-E
RT2								ENTSO-E
RT8								ENTSO-E
RT9								ENTSO-E
Average number of voltage violations/load point ¹								[10]

ALR1-5 RT7	o o o o x	x o	NERC ENTSO-E
Expected number of voltage violations ¹	o o o x o	o x	[10]
RT4			ENTSO-E
RT5	o o o x x	x o	ENTSO-E
RT6			ENTSO-E

(1) Risk, (2) Magnitude, (3) Probability, (4) Frequency, (5) Duration, (6) Deterministic,
 (7) Probabilistic

o = not applicable, x = applicable

¹ This indicator was denoted as an adequacy indicator in [10], however, this does not correspond with the definitions of adequacy and security indicators as adopted in this paper.

5.3. Socio-economic indicators

Socio-economic indicators relate power system reliability to social and economic factors. From a socio-economic perspective, the ideal reliability level is obtained at maximal socio-economic surplus.¹⁷ Socio-economic surplus is defined as the sum of consumer surplus, producer surplus, TSO surplus and government surplus. The surplus equals the value of a particular reliability level minus the cost to obtain a particular reliability level. Socio-economic surplus maximization equals total system cost minimization under two simplifying assumptions: (i) changes in the electricity market should not change the behaviour of electricity market actors, such as producers and consumers, and (ii) changes in the electricity market should have little effect on other markets [39].¹⁸

He et al. denote total system cost as the social cost consisting of the interruption cost and the operating cost. The interruption cost depends on the amount

¹⁷Practical indicators differ from ideal indicators in the sense that practical indicators should be easy to use and all data to calculate the indicator should be available.

¹⁸These assumptions are never fully met. If, for instance, electricity becomes more expensive and consumers' price elasticity is less than one, consumers will buy less electricity and will have less budget to buy other goods.

of load curtailment and the customer interruption cost function, whereas the operating cost depends on the generated power and the operating cost function of the generators, [61]. Besides the generator costs, other costs should be included in the operating cost, such as the cost of line switching, PST tap changing and other reliability actions. Although the cost of these actions is typically lower than the generator costs, it cannot be neglected. Moreover, the operating cost should contain the cost of additional flexibility services that might be required in systems with a high share of RES. As the operating cost focuses on the actions that are taken rather than their outcome, it is denoted as an activity indicator.

Interruption costs have several notions and are based on different parameters. Allan and Billinton specify the customer interruption costs (CIC) and customer outage costs (COC) [10]. CICs are interruption costs per interruption and are used to determine the composite and sector customer damage functions (resp. CCDFs and SCDFs). CICs are typically determined based on surveys. COCs at a particular bus can be deduced from the CDFs, the energy consumed by consumers at that bus and failure rates and repair times, i.e., the frequency of the outage and the outage duration. The SCDFs can be converted into global indices of value of lost load (VOLL) or interrupted energy assessment rate (IEAR) [62]. VOLL expresses the value of unserved energy at a particular location, type of consumer and moment in time, for a particular duration and a particular type of interruption. It is the marginal interruption cost with respect to energy not supplied, i.e., the interruption cost of an additional 1 MWh interruption [39]. Another indicator that quantifies the value of reliability is the willingness to pay (WTP), which represents the consumers' willingness to pay to improve their continuity of supply [27]. VOLL, IEAR and WTP can be considered as criticality indicators, as they are parameters representing how critical reliable electricity supply is for consumers. VOLL is the most widely used indicator of the three and also referred to by ENTSO-E [27, 63].

Based on these criticality indicators, the monetary consequences of interruption for consumers can be estimated. Allan and Billinton define ECOST as the product of IEAR and LOEE and denotes this as expected outage cost. Zhang

and Billinton on the contrary specify ECOST as the annual expected customer
610 damage cost at a specified system service area or load bus. ECOST is in this
case based on the expected energy not supplied (EENS) and the composite cus-
tomer damage function [64].¹⁹ Wang and Billinton use the same formula for
ECOST as Zhang and Billinton, but they give ECOST two different meanings:
‘expected customer interruption cost’ and ‘total system interruption cost’ [65].
615 In the GARPUR project, (expected) interruption cost is defined as the product
of the (expected) energy not supplied and the value of lost load and represent the
negative economic impact on electricity consumers of an electricity interruption
[39]. This indicator is also denoted as social value of EENS [27].

Table 6: Characterization of socio-economic indicators

Indicators	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	Reference
Social welfare/surplus ¹	o	x	o	o	o	x	x	x	o	[39]
Total system cost ¹										[61]
Customer outage cost	o	x	o	o	o	o	x	x	o	[10]
Customer interruption cost										[10]
ECOST										[10, 64, 65]
Expected interruption cost	x	o	o	o	o	o	x	o	x	[39]
Social value of EENS										[27]
Operating cost	o	x	o	o	o	x	o	x	o	[61]

(1) Risk, (2) Magnitude, (3) Probability, (4) Frequency, (5) Duration, (6) System, (7)

End-user, (8) Deterministic, (9) Probabilistic

o = not applicable, x = applicable

¹Both system and end-user related

5.4. Reliability indices

620 NERC’s definition of reliability consists of two concepts: adequacy and se-
curity. This definition is further refined with the identification of specific char-
acteristics that define an adequate level of reliability (ALR) [33, 66]:

¹⁹LOEE, EENS and EUE are essentially the same [10].

- The system is controlled to stay within acceptable limits during normal conditions.
- 625 • The system performs acceptably after credible contingencies.
- The system limits the impact and scope of instability and cascading outages when they occur.
- Facilities are protected from unacceptable damage by operating them within facility ratings.
- 630 • Integrity can be restored promptly if it is lost.
- The system has the ability to supply the aggregate electric power and energy requirements of the electricity consumers at all times, taking into account scheduled and reasonably expected unscheduled outages of system components.

635 In 2007, NERC proposed three major indices, which intend to capture and represent multiple reliability parameters in easy-to-understand reliability performance metrics [26, 67]:

- Reliability performance gap: To measure how far the system is from expected performance under contingencies.²⁰
- 640 • Adequacy gap: To measure the capacity and energy shortage from expected adequacy level under steady-state conditions.²¹
- Violation index: Index based on standardized weights depending on the predefined impact of violating a standard (Violation risk factor (VRF)) and the ex-post assessment of the degree of violation (Violation severity level (VSL)) to measure the reliability improvement from compliance with
- 645 NERC reliability standards [26].

²⁰<http://www.nerc.com/pa/RAPA/PA/Pages/ReliabilityPerformanceGap.aspx>

²¹<http://www.nerc.com/pa/RAPA/PA/Pages/AdequacyGapQuarterlyView.aspx>

In 2010, NERC proposed a severity risk index (SRI)²² and an integrated reliability index (IRI). The IRI consists of three risk-based indices: An event driven index (EDI) [69], a condition driven index (CDI) [70] and a standards/statute driven index (SDI) [66]. The event severity risk index is developed to measure the relative severity ranking of events. The relative severity ranking depends on events' occurrence rates and their impact on the bulk power system, which can be among multiple dimensions, e.g. load or facilities. Different events are combined in the EDI. The CDI is an integrated index combining the different ALR indicators in a single index with appropriate weighing factors. To integrate indices that have different units, five trend ratings are identified to quantify each metric's performance level. The SDI verifies the risk of non-compliance with the standards, taking into account the risk of violating the standards and the impact of this violation [66]. The EDI, CDI and SDI are combined in the IRI with appropriate weighting factors. A consultation of power system stakeholders resulted in feedback and comments on the developed indices, such as about the indices' transparency, the practical meaning of the values of the indices and how to react upon them and the values of the weight factors that are used and how to choose them [71].

Besides the overall reliability level, reliability performance evaluation should also consider the distribution of unreliability among consumers, i.e., the fairness of reliability. To express inequality of the distribution of reliability among consumers in a single value, inequality indices are used. These indices can evaluate part of the social acceptability of reliability decisions. Heylen et al. discuss Gini-based and variance-based inequality indices specified in terms of different adequacy or socio-economic indicators, such as energy not supplied, interruption duration, interruption cost, total cost borne by consumers or RES curtailment. Depending on the applied adequacy or socio-economic indicator, different interpretations of fairness are assessed.

²²Updated in 2014 [68]

675 So far, the main focus was on system-related reliability indices to verify how
close the system is loaded to its limits. Moreover, reliability also depends on the
individual component reliability. Examples of component reliability indicators
are time to repair, operating time between failures, failure rate, failure intensity,
etc. [31, 72]. Specific reliability or performance indicators for power plants
680 are defined, such as unit capability factor, unplanned capability loss factor,
time availability factor, capacity factor, net electrical energy production, forced
outage rate, equivalent forced outage rate and commercial availability. These
indicators differ between different types of generating units [21]. A detailed
discussion of component reliability indicators is out of the scope of this paper.

Table 7: Characterization of reliability indices

Indicators	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	Reference
Probability of failure ¹	o	o	x	o	o	x	o	o	x	[10]
Severity risk index	o	x	o	o	x	x	o	x	o	NERC
Event driven index										NERC
Standards/statute driven index	x	x	o	o	o	x	o	x	o	NERC
Condition driven index	o	x	o	o	o	x	o	x	o	NERC
Inequality of reliability	o	x	o	o	o	o	x	x	o	[73]
Reliability performance gap										NERC
Adequacy gap	o	o	o	x	o	x	o	x	o	NERC
Violation index										NERC

(1) Risk, (2) Magnitude, (3) Probability, (4) Frequency, (5) Duration, (6) System, (7)

End-user, (8) Deterministic, (9) Probabilistic

o = not applicable, x = applicable

Indicators with multiple x in the same section of the table combine multiple characteristics

¹ This indicator is denoted as HLII adequacy indicator in [10], but can be better classified
as a reliability index according to the definitions adopted in this paper.

685 6. Discussion

The overall purpose of indicators is to show how the system under study is
working, to detect potential problems and assess solutions. Although indicators

differ between application contexts, effective indicators have common characteristics [74]:

- 690 • Relevant: They should measure an important aspect of the system;
- Easy to understand, even by non-experts;
- Based on accessible data: Data to determine the indicator values should be readily available or can be collected with reasonable extra effort;
- 695 • Reliable: The information provided by the indicators can be trusted. The reliability of the indicators also depends on the accuracy of the available data.

Important aspects of the system determining the relevance of an indicator relate to the overall objectives of power system operation and the requirements of evolving reliability management. The overall objective of power system operation is specified in the electricity law per country. The Belgian electricity law states for instance that regulation should contribute to the development, in the most cost-effective way, of secure, reliable and efficient, non-discriminating power systems, which are consumer oriented (Art. 23 par. 1.4) [75]. This means that, besides security and adequacy, also cost-effectiveness and the level of discrimination between end-users should be assessed. The requirements and standards of system operation are determined in more detail by the reliability management approach. Scientific literature prescribes that the variability and uncertainty coming with a high share of RES should be adequately considered in future reliability management [6]. Moreover, the characteristics of RES also require the introduction of new flexibility services in power systems to ensure system security and adequacy. Modern technologies that can offer flexibility enable the exploitation of corrective actions in real-time, avoiding unnecessary preventive costs if an appropriate trade-off is made. To make the trade-off between corrective and preventive actions ahead of real time, one should move from deterministic reliability management to probabilistic reliability management based on socio-economic incentives [5]. Besides the fair treatment of end-

consumers in terms of reliability, flexibility providers and RES generation should also be treated fairly to ensure competition in a liberalized market.

First, this section verifies whether indicators proposed by coordinating organizations, such as NERC, ENTSO-E and CEER, comply with the objectives and requirements of evolving reliability management. Indicators currently applied in practice are assessed in terms of four aspects representing the evolutions in reliability management, i.e., do they adequately represent the uncertainty in the system by being probabilistic in nature, do they assess the cost-effectiveness of system operation, do they assess the reliability for RES or flexibility providers and do they address the discrimination between end-users. Second, indicators proposed in scientific literature that can fill the gaps are discussed and analyzed in terms of their data requirements and data availability and accuracy. Based on this analysis, directions for future work are identified.

6.1. Indicators proposed by coordinating organizations

Table 8 summarizes the scope of the security indicators proposed by NERC and ENTSO-E. These indicators mainly focus on the impact on system parameters, such as voltage and overload, load curtailment or the characteristics of events that have occurred. Economic security indicators have not yet been applied in practice. Currently-used security indicators are lagging and deterministic and are especially suitable to evaluate the decision making ex-post, i.e., if the uncertainty is already reduced, to verify whether reliability standards are satisfied.

Table 8: Scope of security indicators proposed by coordinating organizations (NERC/ENTSO-E)

NERC/ENTSO-E	Consequences			
	System parameters	Economic	Curtailment	Characteristics of events
Probabilistic	0/0	0/0	0/0	0/0
Deterministic	4/2	0/0	1/2	5/10

Table 9 summarizes the scope of the adequacy indicators proposed by NERC
 740 and ENTSO-E. Where probabilistic security indicators have not been used in
 practice, the adequacy assessment is partly probabilistic. Most of the adequacy
 indicators focus on the end-consumers. However, ENTSO-E's target methodol-
 ogy for adequacy assessment prescribes to assess the amount of RES curtailment,
 which becomes more important if systems are reaching their inherent flexibility
 745 limits and insufficient alternative flexibility services are available [1]. This ad-
 equacy indicator is directly related to the issue of increasing RES penetration.

Table 9: Scope of adequacy indicators proposed by coordinating organizations
 (NERC/ENTSO-E)

NERC/ENTSO-E		Consumers	RES and flexibility
Probabilistic	Physical	5/2	0/0
	Economic	0/0	0/0
	Discrimination	0/0	0/0
Deterministic	Physical	3/0	0/2
	Economic	0/0	0/0
	Discrimination	0/0	0/0

Coordinating organizations recommend to harmonize the adequacy indica-
 tors used by TSOs to verify the continuity of supply. CEER suggests to use
 750 SAIDI and SAIFI for long interruptions, MAIFI for short interruptions and
 ENS for interruptions at the transmission level [22]. Also the proposal for the
 Clean Energy Package includes directives to harmonize the risk and reliabil-
 ity assessment. It suggests to monitor the security of electricity supply using
 EENS²³ [GWh/year] and LOLE [h/year] [76].

755 Besides the security and adequacy indicators, NERC focuses on system per-
 formance indicators and moves towards integrated reliability indices, combining

²³EENS directly measures the impact of system stress on the quality of service rather than
 through indirect indications, such as the magnitude of line overloads or bus undervoltages
 [60].

different aspects in one value. The advantage of these integrated indices is that focusing on less, well selected indices reduces the complexity of reliability management. However, integrated indices are perceived as less transparent and the values are hard to interpret and react upon adequately. Their practical applicability and usefulness should be proved [71].

Overall, the indicators proposed by coordinating organizations mainly focus on the system security or the impact on consumers. Only two indicators focus on the adequacy of RES and generation, i.e., the RES curtailment and the full load hours of generation proposed by ENTSO-E. The impact of unreliability on flexibility providers, i.e., how often they cannot provide their service to their customers due to network issues, is currently not explicitly assessed. Moreover, the indicators proposed by ENTSO-E, NERC, and CEER are mainly physical indicators and do not assess the cost-effectiveness or the level of discrimination between end-users.

6.2. Complementary indicators and their data requirements

Probabilistic, physical indicators, such as the ones proposed in [4, 58, 59, 60] can be used complementary to the currently-used, deterministic security analysis. These probabilistic indicators take uncertainties related to RES and contingencies into account. A challenge of these indicators is that accurate probabilities for ex-ante calculations, such as the probabilities of occurrence of contingencies, are required. Moreover, the proposed indicators do not assess the cost-effectiveness of system operation, although this is important to make an adequate trade-off between preventive and corrective actions in reliability management.

Socio-economic surplus is denoted as the ideal index for reliability management, because it covers overall costs and benefits of different system stakeholders [39]. However, socio-economic surplus is not easy to use in practical reliability assessment and TSO decision making. Not all data needed to evaluate socio-economic surplus are available at the moment of decision making and some of the data are difficult to obtain. The value of reliability from the customer

perspective is for instance hard to determine in practice, because the societal worth of electric service reliability is very complex and multi-faceted [77]. Several papers suggest to use total system cost in a system cost minimization as an alternative for socio-economic surplus, as it has similar characteristics under certain assumptions [61, 78, 79, 80]. Studies have shown that reliability management based on expected total cost can result in significant cost savings [5, 36]. However, exact values of total system cost are hard to obtain. The different cost terms are sensitive to exogenous factors and need to be estimated if they are not known exactly, which typically leaves room for discussion. Costs of corrective actions are for instance hard to estimate [79]. Also exact VOLL data to calculate interruption costs are not easy to obtain, as they differ over time and depend on external conditions [27].

Inexact VOLL data also challenge the calculation of LOLE thresholds based on cost-incentives. The European commission suggests to calculate the LOLE threshold based on the trade-off between the value of lost load and the cost of new entry of a peak power plant [27]. The optimal LOLE can be calculated based on:

$$\text{Optimal LOLE} = \frac{\text{Capital cost}}{\text{VOLL} - \text{Operating cost}} \quad (1)$$

Although NERC and ENTSO-E had already proposed to use LOLE in a probabilistic adequacy assessment, they do not explicitly mention cost incentives considered in the thresholds and no harmonized European or regional thresholds exist [47]. If we calculate the LOLE thresholds back to the assumed VOLL for constant cost data of the peak power plant, VOLL significantly differs between countries. If we assume a capital cost of €60000/MWh/year and an operating cost of €50/MWh for the peak power plant, Table 10 summarizes the LOLE thresholds currently used in Europe and their corresponding VOLL. If VOLL is correctly estimated, the cost-effectiveness of the level of redundancy can be considered in the adequacy assessment for average conditions. Detailed VOLL data that differ over time are hard to apply in a LOLE assessment, because LOLE is defined over a period of time.

Table 10: The LOLE thresholds and their corresponding VOLL

LOLE [h/year]	VOLL [€/MWh]	Countries [47]
3	20050	Belgium, France, Great Britain
4	15050	The Netherlands
8	7550	Republic of Ireland

Other socio-economic indicators proposed in scientific literature mainly focus on the magnitude of specific effects and are typically deterministic in nature. Moving towards probabilistic reliability management approaches with cost incentives, either in the objective function or in the constraints, requires probabilistic socio-economic indicators. Probabilistic, socio-economic indicators, expressing the risk in terms of costs or surplus, are useful to ensure cost-effectiveness. ECOST is a first step in this direction, but this indicator only focuses on the interruption cost rather than on the total cost.

Besides the magnitude of the socio-economic impact, the importance of fairness is increasingly recognized in the power system literature. Perlaviciute et al. [81] argue that the different drivers for public acceptability, of which fairness is one, should be assessed from the start of a project and during the implementation phase. To verify the fairness of reliability decisions in terms of reliability, system operators and regulators can use inequality indices as proposed in [82].

6.3. Missing indicators and suggestions for future work

Based on the analysis of available indicators, four important directions for future work in a practical and scientific context are determined.

First, the preceding assessment of available indicators revealed that no unified terminology exists for the indicators. To avoid confusion about the definitions of the applied indicators, homogenization of the indicator terminology is an important task.

Second, indicator development should focus on probabilistic indicators covering physical and socio-economic aspects. Besides focussing on the end-consumers

and the system itself, indicators should be developed to assess the adequacy for
835 flexibility providers and generation facilities. Indicator thresholds are also an
important field of study.

Third, the discussion of fairness in a power system context in literature is
merely theoretical so far [82]. Further development of fairness indices towards
practically applicable indices requires that government and regulatory agen-
840 cies determine society's preferences in terms of the definition of fairness, the
consumers' perception of their peers, e.g., are consumers concerned about dif-
ferences between members of the same consumer group or the same region, and
a threshold of the acceptable level of unfairness [83].

Fourth, transmission system operators should analyze how probabilistic se-
845 curity indicators and socio-economic indicators proposed in scientific literature
can contribute to system operation by applying them complementary to the cur-
rent approach. A first step in this direction was made in the GARPUR project,
in which the Icelandic TSO Landsnet has experimented with probabilistic reli-
ability assessment in a pilot test [84]. The main objective of the pilot test was
850 to verify the feasibility of the probabilistic approach, rather than to estimate
potential improvements. Real-time risk information has been provided to the
system operators in the control room using probabilistic indicators, such as the
risk of interruption cost, the residual risk due to omitted contingency states,
probability of one or more faults in the next hour, the probability of being in
855 an acceptable state after one hour and the number of contingencies considered
[85]. The pilot test showed that the ease of use and the transparency of the in-
dicators are as important as their theoretical relevance and reliability to assure
their practical applicability. The operators criticized the lack of transparency
in the approach, e.g., what is the specific reason for an increase in risk. Trans-
860 parency can be provided by optionally offering detailed, qualitative information
to the system operator about how the indicator value is obtained [85]. More-
over, transmission system operators have recognized the importance of accurate
data, such as failure probabilities, and their deficiencies on the domain of data
analysis the last decades. These findings have resulted in the foundation of a

865 data science department at the Norwegian transmission system operator Stat-
nett, which is amongst others focussing on the determination of detailed failure
probabilities [86].

7. Conclusion

Literature on indicators that can be used in power system reliability man-
870 agement is not coherent nor unified. The presented overview, characterization
and classification of indicators provides insight in the available indicators and
their characteristics. Four main classes of indicators can be distinguished each
with their own characteristics: adequacy, security, socio-economic and reliability
indicators.

875 The set of currently-used adequacy indicators contains deterministic and
probabilistic indicators. These adequacy indicators mainly focus on end-consumers'
adequacy, whereas indicators to assess the adequacy for flexibility providers are
not available in practice or in scientific literature. The set of currently-used
security indicators especially lacks probabilistic indicators that adequately rep-
880 resent the uncertainty in power systems resulting from the increasing penetra-
tion of renewable energy sources. Currently-used security indicators are mainly
deterministic, lagging, physical indicators to assess the security of the system
ex-post. Besides the physical indicators, system operators should consider risk-
based socio-economic indicators when making a trade-off between preventive
885 and corrective actions to efficiently integrate flexibility resources in future reli-
ability management.

Besides the relevance of indicators in power system operation, the availabil-
ity and accuracy of the data to calculate the indicator values are important.
Not all data to calculate complementary probabilistic and socio-economic indi-
890 cators are readily available. Probabilistic indicators, as proposed in scientific
literature, rely on accurate failure probabilities, which are hard to obtain in
practice. Moreover, detailed VOLL data or data about the cost of reliability
actions required in socio-economic indicators are also also hard to estimate.

Future work should focus on further developing risk-based indicators to guide
895 the decision-making process of reliability management towards secure and cost-
effective decisions. Increasing focus should be put on the development of indica-
tors to assess the reliability for generators and flexibility providers. Moreover,
the ease of use and transparency of the indicators should be considered in the
development process to ensure their practical applicability. Besides the defini-
900 tions of the indicators, a guideline to determine appropriate thresholds for the
indicators in different systems is as important.

Acknowledgment

The work of Evelyn Heylen is supported by the Research Foundation Flan-
ders (FWO).

8. References

- [1] A. Bloom, U. Helman, H. Holttinen, K. Summers, J. Bakke, G. Brinkman,
A. Lopez, It's indisputable: Five facts about planning and operating mod-
ern power systems, IEEE Power and Energy Magazine 2017;15;6;22–30.
- [2] European Renewable Energy Council, Mapping renewable energy path-
ways towards 2020., [http://www.eufores.org/fileadmin/eufores/
910 Projects/REPAP_2020/EREC-roadmap-V4.pdf](http://www.eufores.org/fileadmin/eufores/Projects/REPAP_2020/EREC-roadmap-V4.pdf); 2011 [accessed 16 August
2018].
- [3] E. Heylen, D. Van Hertem, Importance and difficulties of comparing reli-
ability criteria and the assessment of reliability, Young researchers sympo-
915 sium 2014; EESA.
- [4] M. Ni, J. D. McCalley, V. Vittal, T. Tayyib, Online risk-based security
assessment, IEEE Trans. Power Syst. 2003;18;1;258–65.
- [5] G. Strbac, D. S. Kirschen, R. Moreno, Reliability standards for the oper-
ation and planning of future electricity networks, Foundations and Trends
920 in Electric Energy Systems 2016;1;3;143–219.

- [6] J. McCalley, S. Asgarpour, L. Bertling, R. Billinton, H. Chao, J. Chen, J. Endrenyi, R. Fletcher, A. Ford, C. Grigg, G. Hamoud, D. Logan, A. Meliopoulous, M. Ni, N. Rau, L. Salvaderi, M. Schilling, Y. Schlumberger, A. Schneider, C. Singh, Probabilistic security assessment for power system operations, IEEE Power and Energy Society General Meeting 2004.
- [7] G. Strbac, S. Ahmed, D. Kirschen, R. Allan, A method for computing the value of corrective security, IEEE Trans. Power Syst. 1998;13;3:1096-102.
- [8] F. Xiao, J. D. McCalley, Risk-based security and economy tradeoff analysis for real-time operation, IEEE Trans. Power Syst. 2007;22;4:2287-8.
- [9] J. Arcé, M. Ilic, Managing short term reliability related risks, Energy Laboratory Publication MIT EL 00-007 WP 2000.
- [10] R. Allan, R. Billinton, Probabilistic assessment of power systems, Proceedings of the IEEE 2000;88;2:140 - 62.
- [11] D. Bours, What's in a name? on indicators, measures and metrics, <https://www.climate-eval.org/blog/whats-name-indicators-measures-and-metrics>; 2014 [accessed 16 August 2018].
- [12] OECD, Guidance on developing safety performance indicators related to chemical accident prevention, preparedness and response for public authorities and communities/public, <https://www.oecd.org/chemicalsafety/chemical-accidents/41269639.pdf>; 2008 [accessed 16 August 2018].
- [13] Development Assistance Committee (DAC) Working Party on Aid Evaluation, Glossary of Key Terms in Evaluation and Results Based Management, <https://www.oecd.org/dac/evaluation/2754804.pdf>; 2010 [accessed 16 August 2018].
- [14] United States Agency International Development: Planning and Performance Management Unit, Glossary of evaluation terms, 2009.

- [15] Sharing information to improve evaluation: Use measures, indicators or metrics, http://www.betterevaluation.org/en/plan/describe/measures_indicators; 2017 [accessed 16 August 2018].
- [16] E. Babbie, The Practice of Social Research. 13th ed. Belmont USA: Cengage Learning; 2013.
- [17] A. Hawken, G. L. Munck, Cross-national indices with gender-differentiated data: What do they measure? how valid are they?, Social Indicators Research 2012; 111;3;801-38.
- [18] L. Labate, Metrics, measures and indicators, <https://thecarebot.github.io/metrics-measures-and-indicators/>; 2017 [accessed 16 August 2018].
- [19] J. Endrenyi, Reliability Modeling in Electric Power Systems. 1st ed. Chichester UK: Wiley; 1979.
- [20] R. Billinton, R. N. Allan, Power system reliability in perspective, IET Electronics and Power 1984;30;3;231-6.
- [21] M. Cepin, Assessment of power system reliability. 1st ed. London UK: Springer; 2011.
- [22] CEER, 6th CEER Benchmarking report on quality of electricity and gas supply, http://www.ceer.eu/portal/page/portal/EER_HOME/EER_PUBLICATIONS/CEER_PAPERS/Cross-Sectoral/2016; 2016 [accessed 16 August 2018].
- [23] IEEE Standards board, IEEE std. 859-1987 - IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities, DOI: 10.1109/IEEESTD.1988.86288; IEEE; 1988.
- [24] R. Billinton, R. N. Allan, Reliability of electric systems: An overview In: Hoang Pham, editor. Handbook of Reliability Engineering, 1st ed. London UK: Springer; 2003, p. 512.

- [25] Power Systems Engineering Committee, Reliability indices for use in bulk power supply adequacy evaluation, IEEE Trans. Power App. Syst. 1978;4;1097-103.
- [26] NERC, Towards ensuring reliability: Reliability performance metrics, https://www.nerc.com/comm/PC/Performance%20Analysis%20Subcommittee%20PAS%20DL/Archive/Reliability_Metrics_white_paper.pdf; 2007 [Accessed 16 August 2018].
- [27] European Commission, Identification of appropriate generation and system adequacy standards for the internal electricity market, https://ec.europa.eu/energy/sites/ener/files/documents/Generation%20adequacy%20Final%20Report_for%20publication.pdf; 2016 [accessed 16 August 2018].
- [28] GARPUR consortium, D1.1 State of the art on reliability assessment in power systems, <https://www.sintef.no/projectweb/garpur/deliverables/>; 2014 [accessed 16 August 2018].
- [29] D. Niebur, R. Fischl, Artificial neural networks for static security assessment. In: Warwick K, editor. Artificial intelligence techniques in power systems, 1st ed. London: The Institution of Electrical Engineers; 1997, p 143 - 191.
- [30] A. Monticelli, M. V. F. Pereira, S. Granville, Security-constrained optimal power flow with post-contingency corrective rescheduling, IEEE Trans. Power Syst. 1987;2;1;175-80.
- [31] International Electrotechnical Commission, Electropedia: The world's online electrotechnical vocabulary, <http://www.electropedia.org/>; 2016 [accessed 16 August 2018].
- [32] P. Kundur, J. Paserba, V. Ajjarapu, G. Andersson, A. Bose, C. Canizares, N. Hatziargyriou, D. Hill, A. Stankovic, C. Taylor, et al., Definition and classification of power system stability IEEE/CIGRE joint task force on

- stability terms and definitions, IEEE Trans. Power Syst. 2004;19;3;1387-401.
- [33] NERC, Definition of adequate level of reliability, <https://www.nerc.com/comm/Other/Pages/Adequate%20Level%20of%20Reliability%20Task%20Force%20ALRTF.aspx>; 2007 [accessed 16 August 2018].
- [34] G. Kjølle, O. Gjerde, M. Hofmann, Vulnerability and security in a changing power system, SINTEF Energy Research, Trondheim 2013.
- [35] M. Hofmann, G. Kjølle, O. Gjerde, Development of indicators to monitor vulnerabilities in power systems, PSAM11/ESREL2012.
- [36] E. Heylen, M. Ovaere, G. Deconinck, S. Proost, D. Van Hertem, A multi-dimensional analysis of reliability criteria: From deterministic n-1 to a probabilistic approach, Electric Power Systems Research [Unpublished results].
- [37] S. Meliopoulos, D. Taylor, C. Singh, F. Yang, S. W. Kang, G. Stefopoulos, Comprehensive power system reliability assessment, PSERC Publication 05-13 https://pserc.wisc.edu/documents/publications/reports/2005_reports/; 2005 [accessed 18 August 2018].
- [38] D. Kirschen, K. Bell, D. Nedic, D. Jayaweera, R. Allan, Computing the value of security, IEE Proceedings Generation, Transmission and Distribution 2003;150;6;673-8.
- [39] GARPUR consortium, D3.1 Quantification method in the absence of market response and with market response taken into account, <https://www.sintef.no/projectweb/garpur/deliverables/>; 2016 [accessed 16 August 2018].
- [40] NERC, 2016 probabilistic assessment - technical guideline document, <https://www.nerc.com/comm/PC/PAITF/ProbA%20Technical%20Guideline%20Document%20-%20Final.pdf>; 2016 [accessed 16 August 2018].

- [41] NERC, 2016 probabilistic assessment, https://www.nerc.com/pa/RAPA/ra/Reliability%20Assessments%20DL/2016ProbA_Report_Final_March.pdf; 2017 [accessed 16 August 2018].
- 1035 [42] S. Fockens, A. Van Wijk, W. Turkenburg, C. Singh, A concise method for calculating expected unserved energy in generating system reliability analysis, IEEE Trans. Power Syst. 1991;6;3;1085-91.
- [43] ENTSO-E, ENTSO-E Target Methodology for Adequacy Assessment - Updated version after consultation, https://docstore.entsoe.eu/Documents/SDC%20documents/SOAF/141014_Target_Methodology_for_Adequacy_Assessment_after_Consultation.pdf; 2014 [accessed 16 August 2018].
- 1040
- [44] R. Billinton, R. Karki, A. K. Verma, Reliability and risk evaluation of wind integrated power systems. 1st ed. New Delhi India: Springer; 2013.
- 1045 [45] R. Billinton, S. Kumar, Indices for use in composite generation and transmission system adequacy evaluation, International Journal of Electrical Power & Energy Systems 1990;12;3;147 - 55.
- [46] S. A. Newell, K. Spees, J. P. Pfeifenberger, I. Karkatsouli, N. Wintermantel, K. Carden, Estimating the Economically Optimal Reserve Margin in ERCOT, <http://www.brattle.com/news-and-knowledge/publications/estimating-the-economically-optimal-reserve-margin-in-ercot>; 2014 [accessed 16 August 2018].
- 1050
- [47] CEER, Assessment of electricity generation adequacy in European countries, <https://www.ceer.eu/documents/104400/-/-/a9517a5f-5a98-2974-dd61-e085c7971b53>; 2014 [accessed 16 August 2018].
- 1055
- [48] Royal Academy of Engineering: Council for Science and Technology, GB electricity capacity margin, <https://www.raeng.org.uk/publications/>

- reports/gb-electricity-capacity-margin; 2013 [accessed 16 August 2018].
- [49] IEEE standards association, 1366-2012 - IEEE guide for electric power distribution reliability indices, DOI: 10.1109/IEEESTD.2012.6209381; IEEE; 2012.
- [50] CEER, 4th CEER Benchmarking report on quality of electricity supply, http://www.autorita.energia.it/allegati/pubblicazioni/C08-EQS-24-04_4th_Benchmarking_Report_EQS_10-Dec-2008_re.pdf; 2008 [accessed 16 August 2018].
- [51] W. Li, R. Billinton, Reliability Assessment of Electrical Power Systems Using Monte Carlo Methods. 1st ed. New York USA: Plenum Press; 1994.
- [52] Edison Electric Institute Transmission and Distribution Committee, Guide for reliability measurement and data collection, New York USA: Edison Electric Institute; 1971.
- [53] G. Calabrese, Generating reserve capacity determined by the probability method, Trans. of the American Institute of Electrical Engineers 1947;66;1;1439-50.
- [54] T. E. Dy Liacco, The adaptive reliability control system, IEEE Trans. Power App. Syst. 1967;5;517-31.
- [55] L. H. Fink, K. Carlsen, Operating under stress and strain: Part two of the blackout series, IEEE Spectrum 1978;15;3;48-53.
- [56] R. Billinton, E. Khan, A security based approach to composite power system reliability evaluation, IEEE Trans. Power Syst. 1992;7;1;65 - 72.
- [57] ENTSO-E, System operation guideline, <https://ec.europa.eu/energy/sites/ener/files/documents/SystemOperationGuideline%20final%28provisional%2904052016.pdf>; 2016 [accessed 16 August 2018].

- 1085 [58] E. Ciapessoni, D. Cirio, S. Massucco, A. Pitto, A Probabilistic Risk Assessment and Control methodology for HVAC electrical grids connected to multiterminal HVDC networks, IFAC Proceedings Volumes 2011;44;1;1727-32.
- [59] A. Dissanayaka, U. D. Annakkage, B. Jayasekara, B. Bagen, Risk-based
1090 dynamic security assessment, IEEE Trans. Power Syst. 2011;26;3;1302-8.
- [60] D. S. Kirschen, D. Jayaweera, D. P. Nedic, R. N. Allan, A probabilistic indicator of system stress, IEEE Trans. Power Syst. 2004;19;3;1650-7.
- [61] J. He, L. Cheng, D. S. Kirschen, Y. Sun, Optimising the balance between security and economy on a probabilistic basis, IET generation, transmission
1095 & distribution 2010;4;12;1275-87.
- [62] R. Billinton, J. Oteng-Adjei, Comparison of two alternate methods to establish an interrupted energy assessment rate, IEEE Trans. Power syst. 1987;2;3;751-7.
- [63] ENTSO-E, ENTSO-E Guideline for Cost Benefit Analysis of Grid
1100 Development Projects, <https://docstore.entsoe.eu/Documents/SDC%20documents/TYNDP/ENTSO-E%20cost%20benefit%20analysis%20approved%20by%20the%20European%20Commission%20on%204%20February%202015.pdf>; 2015 [accessed 16 August 2018].
- [64] W. Zhang, R. Billinton, Cost-related reliability evaluation of interconnected
1105 bulk power systems using an equivalent approach, Electric Machines & Power Systems 2000;28;9;793-810.
- [65] P. Wang, R. Billinton, Optimum load-shedding technique to reduce the total customer interruption cost in a distribution system, IEE Proceedings-Generation, Transmission and Distribution 2000;147;1;51-6.
- 1110 [66] NERC, Integrated reliability index concepts, <https://www.nerc.com/comm/PC/Performance%20Analysis%20Subcommittee%20PAS%20DL/>

- Integrated_Reliability_Index_WhitePaper_DRAFT.pdf; 2011 [accessed 16 August 2018].
- [67] NERC, Three-year electric reliability organization performance assessment report, <https://www.nerc.com/gov/Pages/Three-Year-Performance.aspx?RootFolder=%2Fgov%2FThree%20Year%20Performance%20DL%2FThree%20Year%20Assessment%20%2D%20July%201%2C%202009&FolderCTID=0x0120007922CA21FD97BE4E9A2F610283C1C9CB&View={D61B00CD-E83E-4E8E-B09E-DDDF44FD9A51}>; 2009 [accessed 16 August 2018].
- [68] NERC Performance Analysis Subcommittee, SRI enhancement, <https://www.nerc.com/comm/PC/Performance%20Analysis%20Subcommittee%20PAS%202013/SRI%20Enhancement%20Whitepaper.pdf>; 2014 [accessed 16 August 2018].
- [69] NERC, Event driven index, https://www.nerc.com/comm/PC/Performance%20Analysis%20Subcommittee%20PAS%20DL/EDI_Whitepaper.pdf; 2012 [accessed 16 August 2018].
- [70] NERC, Metric performance and condition driven index, https://www.nerc.com/comm/PC/PerformanceAnalysisSubcommitteePASDL/CDI_Whitepaper.pdf; 2012 [accessed 16 August 2018].
- [71] NERC, Integrated reliability index (IRI) concepts - comments and responses, https://www.nerc.com/comm/PC/Performance%20Analysis%20Subcommittee%20PAS%20DL/Archive/IRI_Whitepaper_Comments.pdf; 2011 [accessed 16 August 2018].
- [72] R. Billinton, R. N. Allan, Reliability evaluation of power systems. 1st ed. New York USA: Plenum Press; 1984, Vol. 2.
- [73] M. Ovaere, E. Heylen, S. Proost, G. Deconinck, D. Van Hertem, How detailed value of lost load data impact power system reliability decisions:

- a trade-off between efficiency and equity, KU Leuven Department of Economics Discussion Paper series 2016;16.26.
- [74] Sustainable Measures, Characteristics of effective indicators, <http://www.sustainablemeasures.com/node/92> [accessed 16 August 2018].
- [75] Law regarding the organization of the electricity market, www.ejustice.just.fgov.be/cgi_loi/change_lg.pl?language=nl&la=N&cn=1999042942&table_name=wet [In Dutch]; 1999 [accessed 16 August 2018].
- [76] The European Parliament and the Council, Regulation of the European Parliament and of the Council on risk-preparedness in the electricity sector and repealing, <http://eur-lex.europa.eu/legal-content/EN/TXT/HTML/?uri=CELEX:52016PC0862&from=EN>; 2016 [accessed 16 August 2018].
- [77] L. Goel, Power system reliability cost/benefit assessment and application in perspective, *Computers & electrical engineering* 1998;24;5;315-24.
- [78] E. Karangelos, L. Wehenkel, Probabilistic reliability management approach and criteria for power system real-time operation, *Power systems computation conference* 2016.
- [79] F. Capitanescu, J. M. Ramos, P. Panciatici, D. Kirschen, A. M. Marcolini, L. Platbrood, L. Wehenkel, State-of-the-art, challenges, and future trends in security constrained optimal power flow, *Electric Power Systems Research* 2011;81;8;1731-41.
- [80] J. Condren, T. W. Gedra, P. Damrongkulkamjorn, Optimal power flow with expected security costs, *IEEE Trans. Power Syst.* 2006;21;2;541-7.
- [81] G. Perlaviciute, G. Schuitema, P. Devine-Wright, B. Ram, At the heart of a sustainable energy transition: The public acceptability of energy projects, *IEEE Power and Energy Magazine* 2018;16;1;49-55.

- 1165 [82] E. Heylen, M. Ovaere, G. Deconinck, S. Proost, D. Van Hertem, Fairness and inequality in power system reliability: Summarizing indices, Electric Power Systems Research [Unpublished results].
- [83] E. Heylen, M. Ovaere, G. Deconinck, D. Van Hertem, Fair reliability management: Comparing deterministic and probabilistic short-term reliability management, IEEE Power and Energy Society General Meeting 2018.
1170
- [84] GARPUR consortium, D8.3 Results from near real life pilot testing (Public Summary), <https://www.sintef.no/projectweb/garpur/deliverables/>; 2017 [accessed 16 August 2018].
- [85] S. Perkin, Real-time Weather-dependent Probabilistic Reliability Assessment of the Icelandic Power System, Ph.D. thesis, Reykjavik University
1175 2018.
- [86] T. Trötscher, Estimating the probability of failure for overhead lines, <https://datascience.statnett.no/2018/04/23/estimating-probability-of-failure-overhead-line-lightning/>;
1180 2018 [accessed 16 August 2018].