Fluid temperature predictions of geothermal borefields using load estimations via state observers

Iago Cupeiro Figueroa^{a,b}, Massimo Cimmino^c, Ján Drgoňa^d, Lieve Helsen^{a,b}

^a*University of Leuven (KU Leuven), Department of Mechanical Engineering, 3001 Leuven, Belgium*

^b*EnergyVille, Thor Park 8310, 3600 Genk, Belgium*

^c*École Polytechnique de Montréal, Département de génie mécanique, Montréal, Québec, H3C3A7, Canada*

^d*Pacific Northwest National Laboratory, Richland, WA, United States*

Abstract

Fluid temperature predictions of geothermal borefields usually involve temporal superposition of its characteristic g-function, using load aggregation schemes to reduce computational times. Assuming that the ground has linear properties, it can be modeled as a linear state space system where the states are the aggregated loads. However, the application and accuracy of these models is compromised when the borefield is already operating and its load history is not registered or there are gaps in the data. This paper assesses the performance of state observers to estimate the borefield load history to obtain accurate fluid predictions. Results show that both Time-Varying Kalman Filter (TVKF) and Moving Horizon Estimator (MHE) provide predictions with average and maximum errors below 0.1 °C and 1 °C respectively. MHE outperforms TVKF in terms of n-step ahead output predictions and load history profile estimates at the expense of about 5 times more computational time.

Keywords: Geothermal modeling, Fluid temperature prediction, Load estimation, State observers, Kalman Filter, Moving Horizon Estimation,

Nomenclature

*Corresponding author

Email address: iago.cupeirofigueroa@kuleuven.be (Iago Cupeiro Figueroa)

α	Thermal diffusivity (m s^{-2})	n	Number of instances (-)
Δt	Load aggregation resolution (s)	N	Number of time-steps (-)
		O	Observer
5 Γ	Arrival cost	p	Model parameter (kg s^{-1})
κ	Weighting factor (-)	P	Error covariance matrix
ρ	Density (kg m^{-3})	$\dot{q}$	Thermal power per unit length (W m^{-1})
τ	Moving-backwards time (s)	35	
A	State matrix	$\dot{Q}$	Thermal power (W)
10 AAD	Average absolute temperature difference (K) or ($^{\circ}\text{C}$)	Q	Thermal energy (J)
		r	Radius (m)
$AAOE$	Average absolute output error (K) or ($^{\circ}\text{C}$)	40 R	Thermal resistance (m K W^{-1}) or measurement noise matrix
B	Input matrix	S	Process noise matrix
15 C	Output matrix or Thermal ca- pacity (J/K)	t	Time (s))
c_p	Specific heat capacity (J kg^{-1} K^{-1})	50 T	Temperature (K) or ($^{\circ}\text{C}$)
		u	Model input (W)
d	Buried depth (m) or model dis- turbance	45 v	Model measurement noise
20		V	Volume (m^3)
e	Thickness (m)	w	Model process noise
g	g-Function (-)	$\hat{x}$	Estimated state (W), (K) or ($^{\circ}\text{C}$)
H	Borehole length (m)		
I	Identity matrix (-)	50 x	Model state (W), (K) or ($^{\circ}\text{C}$), or shanking space (m)
25 k	Thermal conductivity (W m^{-1} K^{-1})	y	Model output (K) or ($^{\circ}\text{C}$)
L	Kalman gain	z	Axial direction
$\dot{m}$	Mass flow rate (kg s^{-1})	<i>Subscripts</i>	

55	<i>acc</i>	Accumulated	<i>v</i>	Vertical discretization
	<i>agg</i>	Aggregated	75 <i>x</i>	State
	<i>b</i>	Borehole or borehole wall		<i>Acronyms</i>
	<i>c</i>	Cell		<i>BMS</i> Building Management System
	<i>d</i>	Difference		<i>CHS</i> Cylindrical heat source
60	<i>e</i>	Error		<i>COP</i> Coefficient of performance
	<i>f</i>	Fluid	80 <i>FLS</i>	Finite line source
	<i>fg</i>	Fluid-to-grout		<i>GSHP</i> Ground source heat pump
	<i>fm</i>	Mean/average fluid		<i>ILS</i> Infinite line source
	<i>fm</i>	Measured		<i>KPI</i> Key performance indicator
65	<i>g</i>	Grout		<i>MHE</i> Moving Horizon Estimator or
	<i>gb</i>	Grout-to-wall	85	Moving Horizon Estimation
	<i>gg</i>	Grout-to-grout		<i>RC</i> Resistance-capacitance
	<i>k</i>	Time-step		<i>SSM</i> State-space model
	<i>out</i>	Outlet		<i>TABS</i> Thermally activated building
70	<i>Q</i>	Aggregated loads		system
	<i>s</i>	Soil	90 <i>TES</i>	Thermal energy storage
	<i>sim</i>	Simulation		<i>TRT</i> Thermal response test
	<i>T</i>	Temperatures		<i>TVKF</i> Time-varying Kalman Filter

1. Introduction

Geothermal borefields are composed of multiple drillings of vertical boreholes
95 to extract/inject heat from/into the ground. Typically, each borehole consists of
one or two U-shaped pipes through which water or an anti-freeze mixture is cir-
culated to realize the targeted heat transfer. Borefields are coupled with ground
source heat pump (GSHP) and passive cooling heat exchanger systems, or used

as thermal energy storage (TES) systems to provide efficient heating and cooling
 100 for buildings and districts. The efficiency of these systems is dependent on the
 fluid temperature that leaves the borefield. Therefore, knowing the borefield
 leaving fluid temperature is key both for optimal design and optimal control
 of the geothermal system. To this end, detailed borefield modeling is used to
 ultimately predict the fluid temperatures that leave the geothermal borefield.
 105 A common approach is to separately treat the modeling of the borehole and the
 ground and couple the two models at the borehole wall.

The relation between the borehole wall temperature and the average fluid
 temperature within the borehole is given by the effective borehole thermal re-
 sistance $R_b^* = \frac{T_{fm} - T_b}{\dot{q}_b}$, where T_{fm} is the average fluid temperature, T_b is the
 110 borehole wall temperature and $\dot{q}_b$ is the heat transfer rate (from the borehole to
 the ground) per unit length (W/m) [1]. Both analytical (Multipole, Claesson
 and Hellström [2]) and numerical methods (Finite element method, Lamarche
 et al. [3]) can be used to calculate this resistance. Resistance networks can
 be considered to add more level of detail and evaluate the temperatures in the
 115 different legs of the U-tubes. However, these approaches do not account for the
 transient heat transfer in the grout or the movement of the fluid flow through
 the U-tube legs. The borehole capacity can have a substantial influence as
 demonstrated by Shirazi and Bernier [4] and it can be taken into account by
 adding thermal capacitances to the resistance network [5, 6]. To account for
 120 the heat transfer effects of the fluid flow moving through the piping, the bore-
 hole can be vertically discretized [7, 8]. Each discretization comprises a thermal
 resistance-capacitance (RC) network and they are coupled by advection heat
 transfer equations. Consequently, the vertical variation of the fluid tempera-
 ture is taken into account, improving the accuracy of the borehole outlet fluid
 125 temperature T_{out} .

To model the ground, the pioneer work of Eskilson and Claesson [9] in-
 troduced the so-called 'g-functions', which are dimensionless thermal response
 factors of the ground for a given borefield geometry. In his thesis, Eskilson com-
 puted the g-functions numerically considering the ground as a homogeneous

130 medium, assuming a constant average ground temperature and the same fluid
 inlet and borehole wall temperature for all boreholes. Following the work of
 Eskilson, several authors tried to analytically determine the g-function of the
 borefield using the Infinite Line Source (ILS, Ingersoll and Plass [10]), Cylindri-
 cal Line Source (CLS, Carslaw and Jaeger [11]) and Finite Line Source (FLS,
 135 Claesson and Eskilson [12]) approaches. These approaches determine the tem-
 perature profile in the ground for an individual borehole when a constant heat
 load is applied. As the ground is assumed to be homogeneous, i.e. the ground
 properties are linear, spatial superposition can be applied to obtain the ther-
 mal response of a borefield. Then, temporal superposition can be applied to
 140 obtain the ground response under a variable heat load. However, the number of
 superposition calculations is proportional to the square of the number of time
 steps, therefore escalating the problem complexity as it advances in time. Since
 the loads far in time have less impact than the immediate applied loads, load
 aggregation schemes are proposed to reduce the computational burden. A com-
 145 prehensive review of load aggregation schemes can be found in Mitchell and
 Spitler [13]. Some examples include the ones proposed by Bernier et al. [14]
 and Claesson and Javed [15].

More recently, interest in simpler models oriented towards model-based op-
 timal control has increased. Model-based optimal control aims to minimize an
 150 objective function over a finite period of time, relying on the predictions made
 by the model. A common strategy for these models is to model the heat dif-
 fusion in the ground as a 1D RC network, considering a constant undisturbed
 ground temperature in the far field [16], incorporating the geothermal gradi-
 ent [17] or even taking into account the effects of the fluid mass flow rate [18].
 155 The information about the borefield load history is stored instead within the
 ground nodes. The ground long-term effects, such as thermal interference be-
 tween multiple boreholes or axial heat transfer are often not accounted for,
 however state updates can be introduced to incorporate these [19]. Other au-
 thors prefer data-driven modeling approaches using data from more accurate
 160 models [20, 21]. More recently, Laferriere and Cimmino [22, 23] proposed a

ground model formulation for optimal control based on the thermal response of the borefield.

Either for simulation or optimization, the accuracy of these models to predict the fluid temperature is compromised if the borefield load history is not known. A priori, this lack of information may not be a problem for the assessment and sizing of new and isolated installations, where there is no previous load history. However, in model-based optimal control applications this can lead to issues in the operation phase. The prediction of the fluid temperature significantly influences the efficiency of the GSHP system and its ability to supply passive cooling. Thus, the control decisions taken by the optimal controller are affected by this prediction. An incorrect prediction of the borefield fluid temperature may lead to sub-optimal and detrimental control actions. It is not rare to encounter operating installations which are either not being monitored or lack high-quality data. Moreover, the measurement instruments (e.g., calorimeters) normally measure fluid heat flow rate $\dot{Q}_f$, which does not necessarily coincide with the ground heat flow rate $\dot{Q}_b$ as depicted in Figure 1. Finally, there is always a degree of uncertainty related not only to the measurement data but also to model parameters that can be re-estimated after a period of operation [24] or to the presence of neighbouring boreholes that can interfere with the ground load history [25].

Extending the methodology developed by Cupeiro Figueroa et al. [19, 26], this paper proposes a method to estimate the load history of non-monitored operational borefield installations using state observers to obtain accurate borefield fluid predictions. State observers are feedback systems that provide an estimate of the internal states of a given model from measurements of the inputs and outputs of the real system to minimize the next-step output error. They are widely used in model-based optimal control applications to minimize the error on the current state of the system model and improve the accuracy of the predictions. The performance of these state observers to estimate the borefield load history and predicting the fluid temperature is assessed in both the short and long-term. Section 2 elaborates on the methodology used. Sec-

Figure 1: Distinction between the fluid heat flow $\dot{Q}_f$ and the borefield heat flow $\dot{Q}_b$.

tion 3 describes the case study building from which the data is extracted and further details on the experiment set-up, such as the initialization of the states x_0 . The resulting vectors of aggregated loads and the fluid temperature predic-
195 tions from the simulations are discussed in Section 4. Finally, conclusions are drawn in Section 5.

2. Methodology

Figure 2 shows a schematic of the methodology used in this paper. A generic borefield model is calibrated using the technical datasheets and information
200 from a real installation of an office building located in Dilbeek, Brussels. The model can be represented as a state-space model (SSM) with a parameterized A matrix. The model input u is the heat flow to the fluid $\dot{Q}_f$ and the output y is the mean fluid temperature T_{fm} . The states x of the model are the fluid and grout temperatures and the vector of aggregated loads $\dot{Q}_{agg}$. The parameter
205 p is the mass flow rate through the borefield $\dot{m}$. A further description of the model can be found in Section 2.1. Using a frame of historical data (fluid heat and mass flow rates) stored within the Building Management System (BMS)

Figure 2: Schematic view of the methodology. The model is initiated with a set of states $\mathbf{x}_0$. At each time-step k the borefield model is fed with the required inputs $\mathbf{u}$ and parameters $\mathbf{p}$ extracted from the BMS system, and the states from the previous step. The resulting outputs $\mathbf{y}$ and states $\mathbf{x}$ receive feedback information from the output measurements $\mathbf{y}_m$ to compute a new state vector of estimates $\hat{\mathbf{x}}$.

the model simulation is coupled with the state observer O that uses the BMS measurements y_m to estimate the new vector of states $\hat{x}$ for the next simulation time-step. Three cases are considered: (i) No state observer O is applied, i.e. the simulation is run in open-loop, (ii) the observer O is a Time-varying Kalman Filter (TVKF) and (iii) the observer O is a Moving Horizon Estimator (MHE). More details about the algorithms of the considered estimators can be found in Section 2.2.

2.1. Borefield model

The borefield model is based on the one developed by Laferriere et al. [27]. It uses separate borehole and ground models which are connected through the wall temperature of the borehole. All the n_b boreholes in the field are lumped into one single borehole. The borehole model is discretized in a number of

220 segments n_v along the axial direction. For each vertical discretization, radial
heat transfer is considered through the resistance-capacitance networks devel-
oped by Bauer et al. [5] and shown in Figure 3. We refer to their work for
further details about the calculation of the fluid-to-grout R_{fg} , grout-to-grout
 R_{gg1}, R_{gg2} and grout-to-wall R_{gb} resistances and the grout capacitances C_g . To
225 add the fluid transport component, each discretization i is connected to ad-
vection heat transfer equations. Applying energy balances on the nodes of the
resistance-capacitance network yields:

for the fluid nodes:

$$\rho_f V_{f1,i} c_{p,f} \frac{dT_{f1,i}}{dt} = \frac{T_{g1,i} - T_{f1,i}}{R_{fg}} - \dot{m} c_p (T_{f1,i} - T_{f1,i-1}) \quad (1a)$$

$$\rho_f V_{f2,i} c_{p,f} \frac{dT_{f2,i}}{dt} = \frac{T_{g2,i} - T_{f2,i}}{R_{fg}} - \dot{m} c_p (T_{f2,i} - T_{f2,i+1}) \quad (1b)$$

for the grout nodes:

$$C_g \frac{dT_{g1,i}}{dt} = \frac{T_{f1,i} - T_{g1,i}}{R_{fg}} + \frac{T_{g2,i} - T_{g1,i}}{R_{gg1}} - \frac{T_{g1,i} - T_{b,i}}{R_{gb}} \quad (1c)$$

$$C_g \frac{dT_{g2,i}}{dt} = \frac{T_{f2,i} - T_{g2,i}}{R_{fg}} + \frac{T_{g1,i} - T_{g2,i}}{R_{gg1}} - \frac{T_{g2,i} - T_{b,i}}{R_{gb}} \quad (1d)$$

and for the wall node:

$$\dot{Q}_{b,i} = \frac{T_{g1,i} - T_{b,i}}{R_{gb}} + \frac{T_{g2,i} - T_{b,i}}{R_{gb}} \quad (1e)$$

Analogously, for a double U-tube borehole:

for the fluid nodes:

Figure 3: Radial cross-sections, resistance-capacitance networks and nomenclature used in the borehole model for the i -th discretization: T_f fluid temperatures, T_g grout temperatures, T_b borehole wall temperatures, C_g grout thermal capacities, R thermal resistances, $\dot{Q}_b$ heat flow injected/extracted into/from the ground. The subscripts 1 and 3 refer to the downward-flow legs, while the subscripts 2 and 4 refer to the upward-flow legs. Adaptation from Bauer et al. [5].

$$\rho_f V_{f1,i} c_{p,f} \frac{dT_{f1,i}}{dt} = \frac{T_{g1,i} - T_{f1,i}}{R_{fg}} - \dot{m} c_p (T_{f1,i} - T_{f1,i-1}) \quad (2a)$$

$$\rho_f V_{f2,i} c_{p,f} \frac{dT_{f2,i}}{dt} = \frac{T_{g2,i} - T_{f2,i}}{R_{fg}} - \dot{m} c_p (T_{f2,i} - T_{f2,i+1}) \quad (2b)$$

$$\rho_f V_{f3,i} c_{p,f} \frac{dT_{f3,i}}{dt} = \frac{T_{g3,i} - T_{f3,i}}{R_{fg}} - \dot{m} c_p (T_{f3,i} - T_{f3,i-1}) \quad (2c)$$

$$\rho_f V_{f4,i} c_{p,f} \frac{dT_{f4,i}}{dt} = \frac{T_{g4,i} - T_{f4,i}}{R_{fg}} - \dot{m} c_p (T_{f4,i} - T_{f4,i+1}) \quad (2d)$$

for the grout nodes:

$$C_g \frac{dT_{g1,i}}{dt} = \frac{T_{f1,i} - T_{g1,i}}{R_{fg}} + \frac{T_{g2,i} - T_{g1,i}}{R_{gg1}} + \frac{T_{g3,i} - T_{g1,i}}{R_{gg2}} + \frac{T_{g4,i} - T_{g1,i}}{R_{gg1}} - \frac{T_{g1,i} - T_{b,i}}{R_{gb}} \quad (2e)$$

$$C_g \frac{dT_{g2,i}}{dt} = \frac{T_{f2,i} - T_{g2,i}}{R_{fg}} + \frac{T_{g1,i} - T_{g2,i}}{R_{gg1}} + \frac{T_{g4,i} - T_{g2,i}}{R_{gg2}} + \frac{T_{g3,i} - T_{g2,i}}{R_{gg1}} - \frac{T_{g2,i} - T_{b,i}}{R_{gb}} \quad (2f)$$

$$C_g \frac{dT_{g3,i}}{dt} = \frac{T_{f3,i} - T_{g3,i}}{R_{fg}} + \frac{T_{g2,i} - T_{g3,i}}{R_{gg1}} + \frac{T_{g1,i} - T_{g3,i}}{R_{gg2}} + \frac{T_{g4,i} - T_{g3,i}}{R_{gg1}} - \frac{T_{g3,i} - T_{b,i}}{R_{gb}} \quad (2g)$$

$$C_g \frac{dT_{g4,i}}{dt} = \frac{T_{f4,i} - T_{g4,i}}{R_{fg}} + \frac{T_{g1,i} - T_{g4,i}}{R_{gg1}} + \frac{T_{g2,i} - T_{g4,i}}{R_{gg2}} + \frac{T_{g3,i} - T_{g4,i}}{R_{gg1}} - \frac{T_{g4,i} - T_{b,i}}{R_{gb}} \quad (2h)$$

and for the wall node:

$$\dot{Q}_{b,i} = \frac{T_{g1,i} - T_{b,i}}{R_{gb}} + \frac{T_{g2,i} - T_{b,i}}{R_{gb}} + \frac{T_{g3,i} - T_{b,i}}{R_{gb}} + \frac{T_{g4,i} - T_{b,i}}{R_{gb}} \quad (2i)$$

The mean fluid temperature T_{fm} is given by the average of the inlet and

230 outlet of the borehole:

$$T_{fm} = \begin{cases} \frac{1}{2}(T_{f1,0} + T_{f2,1}) & \text{single U-tube} \\ \frac{1}{4}(T_{f1,0} + T_{f2,1} + T_{f3,0} + T_{f4,1}) & \text{double U-tube} \end{cases} \quad (3)$$

and the total borefield load equals the sum of all the segment loads, multiplied by the number of boreholes n_b :

$$\dot{Q}_b = n_b \sum_{i=1}^{n_v} \dot{Q}_{b,i} \quad (4)$$

Moreover, the following boundary and initial conditions are imposed:

$$\dot{Q}_f = \begin{cases} \dot{m}c_p(T_{f1,0} - T_{f2,1}) & \text{single U-tube} \\ \frac{\dot{m}c_p}{2}(T_{f1,0} - T_{f2,1} + T_{f3,0} - T_{f4,1}) & \text{double U-tube} \end{cases} \quad (5a)$$

$$T_{s,i} = T_{\{f1,f2,f3,f4,g1,g2,g3,g4\},i}(t=0) \quad (5b)$$

$$T_{f2,n_v+1} = T_{f1,n_v} \quad (5c)$$

$$T_{f4,n_v+1} = T_{f3,n_v} \quad (5d)$$

where $T_{s,i}$ is the undisturbed ground temperature in the far field at the
235 discretization i , thus accounting for the geothermal gradient. The borehole
model dynamic equations (Equations 1, 2, 3 and 5b) can be re-arranged and
represented as a state-space model as shown in Equation 6, where A_T , B_T and
 C_T are the matrices of the linear state-space model. A_T represents a time
linear transfer map of the discretized fluid and grout temperatures ($T_{f1,1}$, $T_{f2,1}$,
240 $T_{g1,1}$, $T_{g2,1}$, ...), B_T is the heat gain matrix from the fluid heat flow ($\dot{Q}_f$),
while C_T represents the mapping of the discretized fluid and grout temperatures
to the mean fluid temperature (T_{fm}). The states of the model are the fluid
and grout temperatures for each discretization, represented by the vector¹ $\mathbf{T}$
in Equation 6c. Note that the borehole model $A_T(\mathbf{p})$ matrix is dependant
245 on the mass flow rate circulating through the borefield due to (i) the fluid
transport component and (ii) the variability of R_{fg} with the convective heat
transfer coefficient. As a result, the $A_T(\mathbf{p})$ matrix is parameterized, with the
parameter $\mathbf{p}$ representing the mass flow rate $\dot{m}$. The size of the state-space

¹We represent the vectors with upright boldface notation while the matrices use non-bold italic notation.

model depends on the number of considered vertical discretizations n_v and the
 250 pipe configuration of the borehole (single U-tube or double U-tube).

$$\frac{\partial \mathbf{T}}{\partial t} = A_T(\mathbf{p}) \mathbf{T} + B_T \dot{\mathbf{Q}}_f \quad (6a)$$

$$\mathbf{T}_{fm} = C_T \mathbf{T} \quad (6b)$$

$$\mathbf{T} = [T_{f1,1}, T_{f2,1}, (T_{f3,1}, T_{f4,1}), T_{g1,1}, T_{g2,1}, (T_{g3,1}, T_{g4,1}), \dots]^T \quad (6c)$$

$$\dot{\mathbf{Q}}_f = [\dot{Q}_f]^T \quad (6d)$$

$$\mathbf{T}_{fm} = [T_{fm}]^T \quad (6e)$$

The ground model computes the effective borehole wall temperature in the borefield, T_b , from the temporal superposition of the g -function, $g(t)$ [9, 28, 29] as presented by Equation 7:

$$T_b(t) = \int_0^t \frac{dg}{d\tau} \cdot \frac{\dot{Q}_b(t-\tau)}{2\pi k_s H n_b} d\tau \quad (7)$$

To reduce the computational time, the history of borefield loads, $\dot{Q}_b$, is aggregated using a continuous load aggregation scheme, in line with the continuous
 255 state-space model in Equation 6. Several discrete load aggregation methods are available in the literature with varying levels of performance and computational speed, as analysed by Mitchell and Spitler [13]. Here, a continuous scheme is constructed in analogy with convection phenomena, where historical borefield
 260 loads are akin to loads advected through time, that is :

$$\frac{\partial \dot{Q}_{agg}}{\partial t} = -\frac{\partial \dot{Q}_{agg}}{\partial \tau} \quad (8a)$$

$$\dot{Q}_{agg}(t=0, \tau) = 0 \quad (8b)$$

$$\dot{Q}_{agg}(t, \tau=0) = \dot{Q}_b(t) \quad (8c)$$

where $\dot{Q}_{agg}$ is the load history of the borefield and τ is the time moving backwards through the load history, such that the exact solution to Equation 8 yields $\dot{Q}_{agg}(t, \tau) = \dot{Q}_b(t - \tau)$. A state-space formulation is obtained

by discretizing the load history into load aggregation cells and expressing the τ -
 265 derivative from the cell values of the historical loads (i.e. the aggregated loads).
 A QUICK (Quadratic Upstream Interpolation of Convective Kinetics) method
 [30] is adopted :

$$\dot{Q}_{agg,k} = \frac{\dot{Q}_{agg,k-1/2} - \dot{Q}_{agg,k+1/2}}{\Delta\tau_k} \quad (9a)$$

$$\dot{Q}_{agg,k-1/2} = \frac{\dot{Q}_{agg,k-1} + \dot{Q}_{agg,k}}{2} - \frac{(\tau_k - \tau_{k-1})^2}{8\Delta\tau_{k-1}} \left(\frac{\dot{Q}_{agg,k} - \dot{Q}_{agg,k-1}}{\tau_k - \tau_{k-1}} - \frac{\dot{Q}_{agg,k-1} - \dot{Q}_{agg,k-2}}{\tau_{k-1} - \tau_{k-2}} \right) \quad (9b)$$

$$\dot{Q}_{agg,k+1/2} = \frac{\dot{Q}_{agg,k} + \dot{Q}_{agg,k+1}}{2} - \frac{(\tau_{k+1} - \tau_k)^2}{8\Delta\tau_k} \left(\frac{\dot{Q}_{agg,k+1} - \dot{Q}_{agg,k}}{\tau_{k+1} - \tau_k} - \frac{\dot{Q}_{agg,k} - \dot{Q}_{agg,k-1}}{\tau_k - \tau_{k-1}} \right) \quad (9c)$$

$$\dot{Q}_{agg,1/2} = \dot{Q}_b \quad (9d)$$

where $\dot{Q}_{agg,k}$ is the aggregated load in the k -th aggregation cell, and $\dot{Q}_{agg,k-1/2}$
 and $\dot{Q}_{agg,k+1/2}$ are the interpolated loads at the left and right faces of the k -th
 270 load aggregation cell, respectively.

The load history is discretized into geometrically expanding cells [15] :

$$\Delta\tau_k = \Delta t_0 \cdot 2^{\lfloor \frac{k-1}{5} \rfloor} \quad (10a)$$

$$\tau_k = \sum_{p=1}^k \Delta\tau_p \quad (10b)$$

where Δt_0 is the width of the first aggregation cell. The number of aggregation cells, n_c , is selected such that the time of the last cell, τ_{n_c} , is larger than the maximum simulation time.

275 Each aggregated load $\dot{Q}_{agg,k}$ proportionally contributes to the borehole wall temperature increase/decrease by a weighting factor κ_k given by the discrete form of Equation 7:

$$T_b = \sum_{k=1}^{n_c} \dot{Q}_{agg,k} \kappa_k \quad (11a)$$

$$\kappa_k = \frac{g(\tau_k) - g(\tau_{k-1})}{2\pi k_s H n_b} \quad (11b)$$

The accumulated load in the ground is given by:

$$Q_{acc} = \sum_{k=1}^{n_c} \dot{Q}_{agg,k} \Delta\tau_k \quad (12)$$

Re-arranging equations 9 and 11 results in the linear state-space model represented in Equation 13, where the states of the ground model are the vector of aggregated loads. The size of the state-space model depends on the number of aggregation cells.

$$\frac{\partial \dot{\mathbf{Q}}_{agg}}{\partial t} = A_Q \dot{\mathbf{Q}}_{agg} + B_Q \dot{\mathbf{Q}}_b \quad (13a)$$

$$\mathbf{T}_b = C_Q \dot{\mathbf{Q}}_{agg} \quad (13b)$$

$$\dot{\mathbf{Q}}_{agg} = [\dot{Q}_{agg,1}, \dot{Q}_{agg,2}, \dot{Q}_{agg,3}, \dots, \dot{Q}_{agg,n_c}]^T \quad (13c)$$

$$\dot{\mathbf{Q}}_b = [\dot{Q}_b]^T \quad (13d)$$

$$\mathbf{T}_b = [T_b]^T \quad (13e)$$

where A_Q , B_Q and C_Q are the matrices of the linear state-space model, obtained by combining and rearranging Equations 9 and 11. A_Q represents a time linear transfer map of the space-discretized aggregated heat loads ($\dot{Q}_{agg,1}, \dots, \dot{Q}_{agg,n_c}$) in the load history, B_Q is the heat gain matrix from the borehole heat flow ($\dot{Q}_b$), while C_Q represents the mapping of the aggregated heat loads to the borehole wall temperatures. The borehole and the ground models can be combined into one single SSM model:

$$\frac{\partial \mathbf{x}}{\partial t} = A(p) \mathbf{x} + B \mathbf{u} \quad (14a)$$

$$\mathbf{y} = C \mathbf{x} \quad (14b)$$

$$\mathbf{x} = [\mathbf{T}^T, \dot{\mathbf{Q}}_{\text{agg}}^T]^T \quad (14c)$$

$$\mathbf{u} = [\dot{Q}_f]^T \quad (14d)$$

$$\mathbf{y} = [T_{fm}]^T \quad (14e)$$

290 The model dimensionality includes a large quantity of unmeasured states compared to its number of inputs and outputs and the number of available measurements.

2.2. State estimation

State estimators or state observers are used in models whose states are hidden, i.e. it is not possible to measure all system states. They provide an estimate
 295 of these internal states for a real system from measurements of the inputs and the outputs of the real system. Their main challenge is to solve a problem where the number of knowns (input and output measurements) is smaller than the number of unknowns (states). In the literature, there exist many state estimation methods. We restrict the scope of this work to the family of Bayesian
 300 estimators, which are recommended when: (i) full information about the system dynamic behavior is available and (ii) there exists uncertainty in some of the parameters of the system [31]. Bayesian observers are algorithms based on probabilistic distributions of the process noise² S and measurement noise R . Since
 305 the borefield model is linear, we apply two linear state observers: Time-varying Kalman Filter (TVKF) and Moving Horizon Estimation (MHE).

²In the literature, the process noise matrix is commonly referred as Q . We use the notation S to avoid confusion with the heat flow rates.

Figure 4: Kalman filter representation: The updated states $\hat{\mathbf{x}}_{k|k}$ are estimated using the predicted states $\hat{\mathbf{x}}_{k|k-1}$ and the difference between the output $\mathbf{y}_{k|k-1}$ (resulting from the states $\hat{\mathbf{x}}_{k|k-1}$) and the measurements $\mathbf{y}_{m,k}$.

2.2.1. Time-varying Kalman Filter

The Kalman Filter (KF) is one of the most popular estimation techniques in the literature for many different engineering applications. KF is a simple and practical algorithm that relies on the SSM matrices, and with proper tuning it can achieve excellent performance [32]. A representation of a KF is given in Figure 4. In essence, the KF algorithm can be considered as a discrete two-step feedback system with a proportional gain L . At each time-step k , an update step is made where the predicted states at time-step $k - 1$ are updated using the information from the measurements:

$$\begin{aligned}\hat{\mathbf{x}}_{k|k} &= \hat{\mathbf{x}}_{k|k-1} + L_k(\mathbf{y}_{m,k} - \mathbf{y}_{k|k-1}) \\ &= \hat{\mathbf{x}}_{k|k-1} + L_k(\mathbf{y}_{m,k} - C\hat{\mathbf{x}}_{k|k-1} - D\mathbf{u}_k)\end{aligned}\tag{15a}$$

Then, a prediction step is made where the states at step $k + 1$ are predicted using the physical model with the information at step k :

$$\hat{\mathbf{x}}_{k+1|k} = A\hat{\mathbf{x}}_{k|k} + B\mathbf{u}_k \quad (15b)$$

The Kalman gain L can be computed a priori leading to a Stationary Kalman Filter (SKF), or it can be updated at each time-step extending to a Time-Varying Kalman Filter (TVKF). However, since the borefield model has a parameterized A matrix there is no point in applying SKF. The Kalman gain L for TVKF is given by:

$$L_k = \frac{P_{k|k-1}C^T}{R_k + CP_{k|k-1}C^T} \quad (15c)$$

where P is the error covariance matrix which is also defined by an update-prediction step via Equations 15d and 15e:

$$P_{k|k} = (I - L_kC)P_{k|k-1} \quad (15d)$$

$$P_{k+1|k} = AP_{k|k}A^T + S_k \quad (15e)$$

where I is the identity matrix.

2.2.2. Moving Horizon Estimation

Kalman Filters rely on the information they have from the previous time-step. To increase its accuracy, a constrained dynamic optimization problem can be formulated to reduce the process and measurement noise over the data window. However, it is clear that this full information (FI) estimation problem would grow up in time to a point where its computational burden would become intractable. Moving Horizon Estimation (MHE) is an approximation to this FI estimation. It considers a fixed horizon of previous measurements inside a moving time window that makes the problem feasible in practice. To account for the dropped measurements past the considered time window, an arrival cost term is introduced into the optimization problem [33]. Moreover, constraints on the states and parameters of the model can be enforced as a method to improve the quality of the estimates. Figure 5 illustrates the MHE concept, which can be described by the following optimization problem:

Figure 5: Comparison between Kalman Filter (KF), Full information (FI) estimation and Moving Horizon Estimation (MHE).

$$\min_{\mathbf{x}_{k-N+1}, W, V} \left[\|\Gamma\|_{P^{-1}}^2 + \sum_{i=k-N+1}^{k-1} \|\mathbf{w}_i\|_{S^{-1}}^2 + \sum_{i=k-N+1}^k \|\mathbf{v}_i\|_{R^{-1}}^2 \right] \quad (16a)$$

$$\text{s.t. } \mathbf{x}_{i+1} = A\mathbf{x}_i + B\mathbf{u}_i + E\mathbf{d}_i + \mathbf{w}_i, \quad i \in N_{k-N+1}^{k-1} \quad (16b)$$

$$\mathbf{y}_i = C\mathbf{x}_i + D\mathbf{u}_i + \mathbf{v}_i, \quad i \in N_{k-N+1}^k \quad (16c)$$

$$\mathbf{x}_i \in \mathcal{X}, \quad \mathbf{w}_i \in \mathcal{W}, \quad \mathbf{v}_i \in \mathcal{V}. \quad (16d)$$

where $\mathbf{x}_i$, $\mathbf{u}_i$, $\mathbf{d}_i$, $\mathbf{w}_i$ and $\mathbf{v}_i$ represent the vector of states, inputs, disturbances, process and measurement noise respectively, predicted at the i -th step of the estimation horizon N , and W and V are the concatenation of the vectors $\mathbf{w}_i$ and $\mathbf{v}_i$. Note that index k denotes a current time sample, while index i refers to the time index of the MHE. The predictions are obtained from the prediction model given by Eqs. (16b) and (16c). Limits on state and noise variables are defined by eq. (16d). The term $\|a\|_S^2$ in the objective function represents the weighted squared 2-norm, i.e., $a^T S a$, with the weighting process, noise and error covariance matrices S , R , and P given as positive definite diagonal matrices. The first term of the objective function Γ stands for the so called arrival cost, which represents the summarized effect of data from previous time-steps outside the estimation window N .

3. Virtual experiment set-up

The methodology is applied to the borefield of a cooling-dominated office building located in Dilbeek, Brussels, Belgium. The building conditioned space is 2232 m^2 and is equipped with a borefield of 37x94m deep double-U tubes, distributed around the building separated by an intermediate 6 m as shown by Figure 6.

Further details on the borefield parameters can be found in Table 1. The thermal properties of the ground are extracted from the SmartGeotherm tool [34],

Figure 6: Distribution of the boreholes around the building envelope and hydronic schematic of the building (TABS stands for thermally activated building syste).

which provides information about the ground composition and the average ground thermal conductivity for any location in Flanders, since no thermal-response-test (TRT) is available. The geothermal gradient is calculated using a geothermal heat flow of 0.07 W/m^2 as documented by Earth-Energy-Designer
355 for the location of Brussels [35], which also indicates an undisturbed ground temperature T_s of $9.7 \text{ }^\circ\text{C}$. The resolution of the load aggregation scheme Δt_0 is set to 480 s (8 minutes), which corresponds to the resolution of the monitoring system. All the other parameters are extracted from the installation technical documentation. Two ground-source heat pumps of 70 kW nominal capacity
360 each provide heating to the building, while direct cooling is supplied by means of two heat exchangers. A variable-speed hydraulic pump circulates a mixture of propylene glycol and water at 30% weight with a maximum volumetric flow rate of $38 \text{ m}^3/\text{h}$. Despite being a 10-year-old building, monitored data from the borefield is only available for 1.5 years, as the calorimeters were recently

Table 1: Summary of the borefield parameters of the office building

Borehole parameters				Piping parameters			
Notation	Description	Value	Units	Notation	Description	Value	Units
r_b	Borehole radius	75.0	mm	r_p	Pipe radius	16.0	mm
H_b	Borehole height	94.0	m	k_p	Pipe conductivity	0.42	W/(m.K)
d_b	Borehole burial depth	1.0	m	e_p	Pipe thickness	3.0	mm
n_b	Number of boreholes	37	-	x_C	Pipe spacing	85.0	mm
Ground parameters				Grout parameters			
Notation	Description	Value	Units	Notation	Description	Value	Units
k_s	Ground conductivity	1.30	W/(m.K)	k_g	Grout conductivity	2.35	W/(m.K)
c_s	Ground heat capacity	980	J/(kg.K)	c_g	Grout heat capacity	1550	J/(kg.K)
ρ_s	Ground density	1358	kg/m ³	ρ_g	Grout density	1225	kg/m ³
T_s	Undisturbed ground temperature	9.7	°C				
dT_s/dz	Geothermal gradient	0.05	°C/m				

365 installed. The available data comprises the inlet and outlet temperatures of the
borefield, the fluid flow rate and the fluid heat flow in intervals of 8 minutes. It
has to be noted that the calorimeters are installed in the building cellar, causing
the temperature sensors to converge to the cellar temperature when no flow is
passing through. As we know beforehand that such data are not related to the
370 phenomena investigated, it has been filtered out from the data-set.

Simulations are set up using the BeSim framework in Matlab [36], which
is built upon the modeling and optimization toolbox YALMIP [37]. The opti-
mization problem resulting from the MHE is solved using Gurobi [38]. Table 2
summarizes the simulation conditions applied in this research. The temperature
375 states are initiated at the undisturbed ground temperature, taking into account
the effects of the geothermal gradient. The load history for simulations 1a, 2a
and 3a is initiated as if it was empty. Simulations 1b and 2b are initiated with
an initial guess of aggregated loads which results from a previous simulation
that applies a constant load for 10 years to minimize the error between the sim-
380 ulation mean fluid temperature and the measured one. The process, noise and
covariance matrices are chosen based on a trial-and-error procedure extending
from previous work [19]. Based on the results of the simulations, we decided
not to run an extra simulation 3b with the initial guesses of aggregated loads.

The simulations are run for 585 days of data starting at the end of February

Table 2: Summary of the simulation conditions in the cases considered.

Case	Initial load states ($\mathbf{x}_0$)	Estimator	Estim. matrices		
			S	R	P
1a	Empty	No estimator (Open-loop)	N/A	N/A	N/A
1b	Guess	No estimator (Open-loop)	N/A	N/A	N/A
2a	Empty	TVKF	1e10	1e1	1e1
2b	Guess	TVKF	1e10	1e1	1e1
3a	Empty	TVKF (Borehole model)	1e10	1e1	1e1
		MHE (Ground model)	1e6	1e1	1e1

385 in time-steps of 8 minutes, in order to match with the time resolution of the
 calorimeters and comprising a total number of time-steps $N_{sim} = 105300$. The
 model in Equation 14 is loaded into BeSim and converted from its continuous
 formulation to a discrete 8-minutes resolution formulation using the MATLAB
 embedded function `c2d`. At the start of each time-step k , the A matrix of the
 390 borefield model is re-computed using the mass flow rate measurement from the
 calorimeter. In the open-loop simulations 1a and 1b, the output (i.e. the mean
 fluid temperature) at time-step k and the predicted state vector at the time-step
 $k + 1$ are calculated using Equations 14a and 14b. In simulations 2a and 2b, at
 each time-step, the need for pre-filtering the measurement data is checked first
 395 to assess whether the measured data is corrupted. If the data point is valid,
 TVKF is applied and the state vector is updated using Equations 15c and 15a
 to compute the new state prediction at $k + 1$ (Equation 15b) and the estimated
 output. The error covariance matrix P is also updated and then predicted by
 Equations 15d and 15e. If the data is filtered out, the corresponding time-step
 400 is simulated in open-loop using Equations 14 and 14b.

To reduce the complexity of the MHE optimization in simulation 3a, the es-
 timator is only applied to the ground model, thus avoiding the implementation
 of the parameterized A matrix in the optimization formulation. This is justi-
 fied since the long-term dynamics of the model are stored within the ground
 405 load states, while the short-term dynamics are stored within the temperature

states. Hence, as in simulations 2a and 2b, TVKF is applied first to obtain an initial set of state estimates. Using the resulting estimates of the borehole wall temperature T_b as the reference value and $\dot{Q}_b$ as the input value, MHE is then applied to the ground model with a window frame of 1 day ($N = 180$)
410 to refine the estimates of the ground loads. The optimization to find the set of aggregated load estimates $\hat{\mathbf{Q}}_{\text{agg}}$ is therefore formulated at each time-step k with the following constraints:

$$\min_{\hat{\mathbf{Q}}_{\text{agg}}^{k-N+1}, W, V} \sum_{i=k-N+1}^{k-1} \|\mathbf{w}_i\|_{S^{-1}}^2 + \sum_{i=k-N+1}^k \|\mathbf{v}_i\|_{R^{-1}}^2 \quad (17a)$$

$$\text{s.t. } \dot{\mathbf{Q}}_{\text{agg}}^{i+1} = A_Q \dot{\mathbf{Q}}_{\text{agg}}^i + B_Q \dot{\mathbf{Q}}_{\text{bi}} + \mathbf{w}_i, \quad i \in N_{k-N+1}^{k-1} \quad (17b)$$

$$\mathbf{T}_{\text{bi}} = C_Q \dot{\mathbf{Q}}_{\text{agg}}^i + \mathbf{v}_i, \quad i \in N_{k-N+1}^k \quad (17c)$$

$$\hat{Q}_{agg,j,i} = \dot{Q}_{agg,j,i} \quad i \in N_{k-N+1}^k \quad (17d)$$

$$j \in 1, 2 \dots m$$

$$\hat{Q}_{acc,i} \geq 0 \quad (17e)$$

$$\hat{\mathbf{Q}}_{\text{agg},i} \in \mathcal{X}, \quad \mathbf{w}_i \in \mathcal{W}, \quad \mathbf{v}_i \in \mathcal{V}. \quad (17f)$$

where m represents the aggregation cell where the load history becomes unknown, and $\dot{Q}_{agg,j,i}$ and $\hat{Q}_{agg,j,i}$ represent the predicted and estimated aggregated load in the j -th cell at the i -th MHE time-step. As the simulation
415 problem advances in time, the point where the load history is unknown is further in the past and consequently the number of states to be guessed becomes smaller. This feature is enforced by constraint (17d): the first aggregation cells keep the value from the previous prediction step while the cells beyond the
420 point m until n_c have a higher degree of freedom. Additionally, constraint (17e) forces the ground load balance to be positive, in accordance to what is expected from a cooling-dominated building. Thus, no arrival cost Γ is defined as the information from previous history is implicitly included within the formulated constraints. The MHE state, process and noise bounds (Equation 17f) are kept
425 within $\pm 3\text{E}5 \text{ W}$, $\pm 1\text{E}2 \text{ W}$ and $\pm 1\text{E}-1 \text{ K}$ respectively. The optimization vari-

ables include: the estimated states $\hat{\mathbf{Q}}_{\text{agg}}$ over the horizon N , the estimated state update error W and the estimated measurement error V . The first element of the optimized estimated states over the horizon $\hat{\mathbf{Q}}_{\text{aggk-N+1}}$ is selected and the current estimated states $\hat{\mathbf{Q}}_{\text{aggk}}$ are calculated by integration using W via the so-called state condensing method [39]. This technique can efficiently reduce the number of optimization variables and as such speed up the solver.

4. Results and discussion

The main objective of the estimators is to reduce the 1-step ahead output error between the estimated output and the real measurement $\mathbf{y}_e = \hat{\mathbf{y}} - \mathbf{y}_m$. However, the predictions of the fluid temperatures in the longer-term are also of interest. Section 4.1 elaborates on the results obtained from the estimators with a focus on 1-step predictions, while Section 4.2 evaluates the performance of the estimators in the longer run. Please note that the model output y in this case is the mean fluid temperature T_{fm} .

4.1. 1-step ahead predictions

The 1-step ahead output error results are evaluated towards the following key performance indicators (KPIs), summarized in Table 3:

- the average absolute output error ($AAOE = \sum_{k=1}^{N_{sim}} |\mathbf{y}_{e,k}| / N_{sim}$),
- the absolute maximum output error ($\max |\mathbf{y}_e|$),
- the mean output error ($\overline{\mathbf{y}_e}$), and
- the average simulation time per time-step ($t_{sim,step} = t_{sim} / N_{sim}$).

Figure 7 compares the box plots of the output errors $\mathbf{y}_e$ for the different simulations cases (as listed in Table 2 for the full period of 585 days). The open-loop simulation (1a) clearly underpredicts the fluid temperature of the system, in accordance to our expectations from the load history of a cooling-dominated building. Simulation 1b shows that this effect can be mitigated by

Table 3: 1-step ahead output numerics.

Case	AAOE [K]	$\bar{\mathbf{y}}_e$ [K]	$\max \mathbf{y}_e $ [K]	$t_{sim,step}$ [s]
1a	2.50E0	-2.50E0	7.62E0	1.34E-2
1b	6.47E-1	-2.14E-1	5.69E0	1.40E-2
2a	6.39E-2	-5.63E-2	8.71E-1	1.65E-2
2b	3.47E-2	-7.90E-3	7.58E-1	1.71E-2
3a	2.59E-2	1.43E-5	6.38E-1	8.81E-2

a reasonable guess of the annual load imbalance of the ground, by modifying Equation 8b to include the annual load imbalance at all times from the start of system operation (which is taken at 10 years) until the start of the simulation:

$$\dot{Q}_{agg}(t = 0, \tau) = \dot{Q}_{annual}, \tau \leq 10 \text{ years} \quad (18)$$

455 All three simulation cases with an estimator implemented (2a, 2b and 3a) outperform the simulations without, with an output error typically an order of magnitude lower. A closer look at the output KPIs can be found in Table 3. It is shown that, with a reasonable estimate of the previous history, TVKF performance can be increased. With the adequate selection of the constraints, MHE
460 outperforms TVKF in terms of error defined KPIs regardless of the previous load history estimate. However, this performance increase comes at the cost of about 5 times more computation time per simulation step as MHE requires to solve an optimization problem.

To enable minimization of the 1-step ahead output error, the estimators
465 have a direct effect on the temperature states of the model, i.e. borehole fluid, grout and wall temperatures, as their influence on the short-term dynamics is higher. Contrary to the output evaluation, there is no direct measurement of these states, consequently we analyze the temperature differences on the temperature states $\mathbf{x}_d$ between open-loop simulations and applying TVKF. Note
470 that only TVKF evaluation is done since simulation case 3a uses this state observer to estimate the temperature states. Analogously to the previous case,

Figure 7: Box plots of the estimated output open-loop/estimation errors for the different experiments.

Table 4: Temperature state difference numerics.

State set	Difference 1a-2a			Difference 1b-2b		
	AAD [K]	$\bar{\mathbf{x}}_{\mathbf{d}}$ [K]	$\max \mathbf{x}_{\mathbf{d}}$ [K]	AAD [K]	$\bar{\mathbf{x}}_{\mathbf{d}}$ [K]	$\max \mathbf{x}_{\mathbf{d}} $ [K]
Fluid	2.06E0	-2.02E0	1.28E1	7.36E-1	1.45E-1	1.05E1
Grout	2.06E0	-2.06E0	4.34E0	4.33E-1	-1.51E-1	3.72E0
Wall	2.00E0	-2.00E0	3.81E0	4.11E-1	-1.43E-1	2.20E0
Total	2.12E0	-2.12E0	1.28E1	4.63E-1	-1.60E-1	1.05E1

the evaluation is done based on the following KPIs, summarized in Table 4:

- the average absolute temperature difference ($AAD = \sum_{k=1}^{N_{sim}} |\mathbf{x}_{\mathbf{d},k}| / (n_x N_{sim})$),
- the absolute maximum temperature difference ($\max |\mathbf{x}_{\mathbf{d}}|$), and
- the mean temperature difference ($\bar{\mathbf{x}}_{\mathbf{d}}$) for each set of fluid, grout and wall temperatures n_x .

On average, TVKF needs to correct about 2.1 °C when the model is initiated with an empty load history and 0.5 °C if an estimate of the load history is first provided, pointing again towards a cooling-dominated building. As expected, these differences are higher the faster the dynamics of the states are. The fluid temperatures have the fastest dynamics, and the wall temperatures the slowest. Since the aggregated load states travel in time, the same analysis is not repeated for that set of states.

Figure 8 shows the accumulated load in the ground (given by Equation 12) over the simulation time. When the model is initiated without load history, it is observed from the open-loop simulations that despite being a cooling-dominated building, over the considered period the ground experienced a negative balance, more typical for heating-dominated buildings. Applying TVKF slowly corrects the negative imbalance towards a positive one to reduce the 1-step ahead output error. This correction effect is no longer needed when the states initial guess is more accurate, as it can be observed from the trajectories in experiments 1b and 2b. On the other hand, despite being initiated without load history, the MHE accumulated load immediately jumps to a different order of magnitude thanks

Figure 8: Accumulated ground load over the operation period shown during the simulation period.

to the constraints formulated in the optimization. The observed oscillations can
 495 be explained due to the high degree of freedom that the load states have from
 the point where the load history becomes unknown. Moreover, as the loads far
 away in time have a lower impact on the wall temperatures, to obtain a small
 change in the fluid temperature it is necessary a big change in the loads far in
 the past. A constraint on the accumulated load rate of change could be added
 500 to limit this effect and have a smoother load, however by doing so we found that
 this led to infeasible computational times.

The load correction effect seen in TVKF has a larger effect in the first load
 states, as it can be pointed out from Figure 9. The fluid load is represented
 from the steady-state time which is the characteristic time of the boreholes
 505 ($t_b = 5r_b^2/\alpha_s$) until the end of the simulation period. In the long-term, the
 fluid and ground energy should be almost coincidental, however this is not the

case when TVKF is being applied. This effect can be explained by looking at Equation 15a, where all load and temperature states are updated proportionally to the computed Kalman Gain L_k . Comparing simulation cases 1a and 2a, the
510 cells that are empty, i.e. the load history before the simulation, are barely affected. Even by introducing a load history as in simulation case 2b, the variation of the first cells that affect the immediate load history has a larger cumulative effect in time, producing the load mismatch between ground and fluid within the 585 days simulation period. An additional reason that causes
515 the mismatch is associated with the update of the temperature states. By doing so, energy from the soil which was not registered through the fluid energy balance is being introduced/removed. This inherent feature of TVKF does not occur in MHE, where due to the constraints applied the load history during the simulation period is not affected, focusing more on finding a combination of the
520 unknown aggregation cells that minimizes the borehole wall temperature error.

4.2. *n-step ahead predictions*

To analyze the performance of the estimators when there is a gap in the data or towards optimal control applications, we analyse the accuracy of open-loop simulations after initialization of the model through varying periods of
525 closed-loop simulations. Closed-loop simulations are run for cases 2a, 2b and 3a. After each month of simulation, an open-loop simulation is started using the estimated states of the closed-loop simulations and the measured loads, and the obtained fluid predictions over time horizons of 1 hour, 6 hours, 24 hours, 3 days, 1 week and 1 month are compared to the monitored data. Figure 10
530 shows the values of $AAOE$, $\max \mathbf{y_e}$, and $\overline{\mathbf{y_e}}$ for the simulation periods of 1 hour, 6 hours, 24 hours, 3 days, 1 week and 1 month, starting after different periods of estimates. In general, and in line with our expectations, the errors increase with the considered simulation period for all the considered estimators. For a simulation time of 24 hours, the TVKF output error can average more than 1
535 $^{\circ}\text{C}$ if no estimate of the previous load history is provided beforehand, slowly returning to the underestimation of 2 $^{\circ}\text{C}$ given by the open-loop simulation 1a.

Figure 9: Histogram of aggregated loads and cumulative ground and fluid load at the end of the simulation. The fluid load is represented from t_b till the end of the simulation period. Each bar represents the aggregated load state within the corresponding cell, positioned relatively to the current instant (cells on the right side are closer to the present). The green region corresponds to the simulation period (585 days). The red region corresponds to the building operation period (10 years). The grey period comprises the remaining cells until τ_{n_c} .

Figure 10: n-step ahead output KPIs after a period of estimates given by the x-axis for the different estimation experiments 2a, 2b and 3a.

The same trend is seen when the estimation of the previous load is provided, with TVKF returning to the underestimates of $0.5\text{ }^{\circ}\text{C}$ given by the open-loop simulation 1b. In these cases, we do not recommend TVKF for n-step output predictions longer than 6-24 hours. On the other hand, MHE is able to keep the average errors under $0.5\text{ }^{\circ}\text{C}$ even after long periods of time of 1 month and without previous initial estimate of loads provided. The length of the estimation period does not seem to have a clear effect on reducing the output errors, but depending on the time frame the open-loop simulation starts the error can be higher or lower. Based on the open-loop simulations with estimates from the estimation 2a, we believe that this feature is related to the seasonality of the loads. The higher errors occur around month 5 which corresponds to the end of the cooling season, increasing the effect of the previous load history. On the other hand, lower errors occur at the end of the heating season where the surrounding ground is colder, compensating for the effect of the previous load history.

The best performance estimator (MHE, experiment 3a) is selected and compared against the open-loop simulation with an initial guess of the load history

to evaluate the increase in performance. After each month of simulation, the
 555 values of $AAOE$, $\max \mathbf{y}_e$, and $\overline{\mathbf{y}_e}$ for the coming simulation periods of 1 hour,
 6 hours, 24 hours, 3 days, 1 week and 1 month are evaluated for the open-loop
 simulation. Results are shown in Figure 11, where it can be seen the lower errors
 obtained by the estimator. The provided initial load history estimate obtained
 by the manual tuning was selected to minimize the error over the whole sim-
 560 ulation period, however the error does not present a constant trend, which is
 probably caused by uncertainties such as the ground conductivity or the undis-
 turbed ground temperature. In that sense, the estimator is able to help with
 these kinds of uncertainties minimizing the error in the prediction of the fluid
 temperature.

565 5. Conclusions

Knowledge of borefield load history is necessary to get accurate predictions
 of the working fluid temperature for design, monitoring and optimal control
 of geothermal systems. However, lack of monitoring data can lead to large
 uncertainties on estimating this load history.

570 This research presents a methodology to estimate the unknown load his-
 tory of borefields based on state observers with the objective of getting better
 predictions of the fluid temperatures. First, technical information from a real
 installation is used to calibrate a physics-based borefield model. This calibrated
 model is then implemented in a simulation environment together with state es-
 575 timator algorithms that estimate the load history, using real operational data.
 Since the borefield dynamics can be modeled in a linear way, two linear state
 estimators are investigated: Time-Varying Kalman Filter (TVKF) and Moving
 Horizon Estimator (MHE). Additionally, we investigate the effect of having a
 previous estimate of the load history. Finally, simulations are run in open-loop
 580 after a period of estimates to assess the performance of the estimators in the
 longer run. The estimators are compared between them and against the case
 where a previous estimate of the load history is provided.

Figure 11: n -step ahead output KPIs after a period of simulation/estimates given by the x-axis for the experiments 1b (load history initial guess) and 3a (MHE).

Both observers provide excellent results in predicting the borefield fluid temperature, with average and maximum 1-step ahead errors below $0.1\text{ }^{\circ}\text{C}$ and $1\text{ }^{\circ}\text{C}$ respectively when compared to the real measurement data, in contrast to the average and maximum errors of $2.5\text{ }^{\circ}\text{C}$ and $7.62\text{ }^{\circ}\text{C}$ respectively of the open-loop simulation. To minimize this error, the estimators have a direct influence on the temperature states of the model, which contain the fast-dynamics information, and consequently the load is modified. This, however, comes with a mismatch between the cumulative ground and fluid loads in the known load history in the case of TVKF, independently of whether a previous unknown load history guess is provided or not. This feature can be corrected with the aid of constraints in the MHE formulation, therefore having a more realistic full load history profile over time. When assessing the open-loop n-step output errors after a period of estimates, it is observed that the error converges to the values of the full open-loop simulations for TVKF the further away the prediction is. The period of estimates does not seem to have a clear effect on the error reduction, but the time-frame where the open-loop simulations start does. MHE excels in keeping the output errors under $0.5\text{ }^{\circ}\text{C}$ even after one month of open-loop simulation time and without a previous guess of the unknown load. The drawback of MHE is its increased computational burden, about 5 times higher than TVKF per time-step.

A raw estimation of the borefield load history which does not need to match the actual complete history can already get sufficiently accurate fluid temperature predictions. However, the estimators are able to get better fluid predictions in the short and long term compared to the case where the past load history is manually estimated, and they converge even by providing an initial inaccurate load estimate.

Future work can be directed towards the different individual aspects of the approach. The proposed discretized SSM model could be evaluated for different sampling times, different from the data acquisition resolution. The work on TVKF should be aimed at decoupling the Kalman Gain between the borehole and the ground model. Concerning the MHE, further tuning of the MHE

optimization problem parameters and its formulation can be explored. For in-
615 stance, different MHE estimation windows can be evaluated and compared to
a full information optimization problem that takes into account the whole data
set. The MHE accumulated load oscillations could be filtered out by introducing
a constraint on the accumulated load variation or post-processing the resulting
accumulated load by using a time-average approach. Finally, the application
620 of the state observers to an optimal control problem or a case where exist un-
accounted neighbouring ground source heat pump systems that affect the load
history could be explored.

Disclosure statement

No potential conflict of interest was reported by the authors.

Acknowledgements

The authors would like to acknowledge the funding of their research work by
the EU within the H2020-EE-2016-RIA-IA programme for the project ‘Model
Predictive Control and Innovative System Integration of GEOTABS;-) in Hybrid
Low Grade Thermal Energy Systems - Hybrid MPC GEOTABS’ [grant number
630 723649 - MPC-; GT]. Furthermore, the InnoEnergy PhD School Programme and
the European Institute of Technology (EIT) are acknowledged for supporting
the international mobility from which this work was emerged.

This work emerged from the IBPSA Project 1, an international project con-
ducted under the umbrella of the International Building Performance Simulation
635 Association (IBPSA). Project 1 will develop and demonstrate a BIM/GIS and
Modelica Framework for building and community energy system design and
operation.

Declarations of interest

None.

640 **References**

- [1] S. Javed, J. Spitler, Accuracy of borehole thermal resistance calculation methods for grouted single U-tube ground heat exchangers, *Applied Energy* 187 (2017) 790 – 806. doi:<https://doi.org/10.1016/j.apenergy.2016.11.079>.
- 645 [2] J. Claesson, G. Hellström, Multipole method to calculate borehole thermal resistances in a borehole heat exchanger, *HVAC&R Research* 17 (6) (2011) 895–911.
- [3] L. Lamarche, S. Kajl, B. Beauchamp, A review of methods to evaluate borehole thermal resistances in geothermal heat-pump systems, *Geothermics* 39 (2) (2010) 187 – 200. doi:<https://doi.org/10.1016/j.geothermics.2010.03.003>.
- 650 [4] A. S. Shirazi, M. Bernier, Thermal capacity effects in borehole ground heat exchangers, *Energy and Buildings* 67 (2013) 352 – 364. doi:<https://doi.org/10.1016/j.enbuild.2013.08.023>.
- 655 [5] D. Bauer, W. Heidemann, H. Müller-Steinhagen, H.-J. Diersch, Thermal resistance and capacity models for borehole heat exchangers, *International Journal of Energy Research* 35 (4) (2011) 312–320. doi:[10.1002/er.1689](https://doi.org/10.1002/er.1689).
- [6] A. Zarrella, M. Scarpa, M. D. Carli, Short time step analysis of vertical ground-coupled heat exchangers: The approach of carm, *Renewable Energy* 36 (9) (2011) 2357 – 2367. doi:<https://doi.org/10.1016/j.renene.2011.01.032>.
- 660 [7] P. Pasquier, D. Marcotte, Joint use of quasi-3D response model and spectral method to simulate borehole heat exchanger, *Geothermics* 51 (2014) 281 – 299. doi:<https://doi.org/10.1016/j.geothermics.2014.02.001>.
- 665 [8] D. Bauer, W. Heidemann, H.-J. Diersch, Transient 3D analysis of borehole heat exchanger modeling, *Geothermics* 40 (4) (2011) 250 – 260. doi:<https://doi.org/10.1016/j.geothermics.2011.08.001>.

- [9] P. Eskilson, Thermal analysis of heat extraction boreholes Ph.D (Doctoral dissertation, Thesis). Department of Mathematical Physics, University of Lund Lund, Sweden (1987).
- [10] L. Ingersoll, H. Plass, Theory of the ground pipe source for the heat pump, ASHRAE Transactions 54 (1948) 339–348.
- [11] H. S. Carslaw, J. C. Jaeger, Conduction of heat in solids, Oxford: Clarendon Press, 1959, 2nd ed.
- [12] J. Claesson, P. Eskilson, Conductive heat extraction to a deep borehole: Thermal analyses and dimensioning rules, Energy 13 (6) (1988) 509–527.
- [13] M. S. Mitchell, J. D. Spitler, Characterization, testing, and optimization of load aggregation methods for ground heat exchanger response-factor models, Science and Technology for the Built Environment 25 (8) (2019) 1036–1051. arXiv:<https://doi.org/10.1080/23744731.2019.1648936>, doi:10.1080/23744731.2019.1648936, URL <https://doi.org/10.1080/23744731.2019.1648936>
- [14] M. A. Bernier, P. Pinel, R. Labib, R. Paillot, A multiple load aggregation algorithm for annual hourly simulations of gchp systems, HVAC&R Research 10 (4) (2004) 471–487.
- [15] J. Claesson, S. Javed, A load-aggregation method to calculate extraction temperatures of borehole heat exchangers, ASHRAE Transactions 118 (1) (2012) 530–539.
- [16] C. Verhelst, L. Helsen, Low-order state space models for borehole heat exchangers, HVAC&R Research 17 (2011) 928–947. doi:10.1080/10789669.2011.617188.
- [17] H. J. Witte, A. Cazorla-Marín, J. M. Corberán, An efficient borehole heat exchanger model for the analysis of transient thermal response: comparison with some existing models, in: Proceedings of EnerSTOCK 2018, Adana (Turkey), 25-28 April 2018.

- [18] I. Cupeiro Figueroa, D. Picard, L. Helsen, Short-term modeling of hybrid geothermal systems for model predictive control, *Energy and Buildings* 25 (8) (2019) 1095–1110. doi:10.1080/23744731.2019.1620564.
- [19] I. Cupeiro Figueroa, J. Drgoña, L. Helsen, State estimators applied to a linear white-box geothermal borefield controller model, in: *Proceedings of International Building Simulation Conference 2019*, 2019, Rome (Italy), 3-5 September 2019.
- [20] F. De Ridder, M. Diehl, G. Mulder, J. Desmedt, J. Van Bael, An optimal control algorithm for borehole thermal energy storage systems, *Energy and Buildings* 43 (10) (2011) 2918 – 2925. doi:10.1016/j.enbuild.2011.07.015.
- [21] E. Atam, D. O. Schulte, A. Arteconi, I. Sass, L. Helsen, Control-oriented modeling of geothermal borefield thermal dynamics through Hammerstein-Wiener models, *Renewable Energy* 120 (2018) 468–477. doi:10.1016/j.renene.2017.12.105.
- [22] A. Laferrière, M. Cimmino, Model predictive control applied to residential self-assisted ground source heat pumps, in: *Proceedings of International Ground Source Heat Pump Association Research Track*, 2018, Stockholm (Sweden), 18-20 September 2018.
- [23] A. Laferrière, M. Cimmino, Linear model predictive control for the reduction of auxiliary electric heating in residential self-assisted ground-source heat pump systems, *Science and Technology for the Built Environment* 25 (8) (2019) 1095–1110. doi:10.1080/23744731.2019.1620564.
- [24] A. R. Puttige, S. Andersson, R. Östin, T. Olofsson, Improvement of borehole heat exchanger model performance by calibration using measured data, *Journal of Building Performance Simulation* 13 (4) (2020) 430–442. arXiv:https://doi.org/10.1080/19401493.2020.1761451, doi:10.1080/19401493.2020.1761451.
URL https://doi.org/10.1080/19401493.2020.1761451

- 725 [25] M. L. Fasci, A. Lazzarotto, J. Acuña, J. Claesson, Analysis of the thermal interference between ground source heat pump systems in dense neighborhoods, *Science and Technology for the Built Environment* 25 (8) (2019) 1069–1080. doi:10.1080/23744731.2019.1648130.
- [26] I. Cupeiro Figueroa, J. Drgoña, M. Abdollahpouri, D. Picard, L. Helsen, 730 State observer for optimal control using white-box building models, in: *Proceedings of Purdue Herrick Conferences*, 2018, West Lafayette (USA), 9-12 July 2018.
- [27] A. Laferrière, M. Cimmino, D. Picard, L. Helsen, Development and validation of a full-time-scale semi-analytical model for the short- and long-term 735 simulation of vertical geothermal bore fields, *Geothermics* 86 (2020) 101788. doi:https://doi.org/10.1016/j.geothermics.2019.101788.
- [28] M. Cimmino, M. Bernier, A semi-analytical method to generate g-functions for geothermal bore fields, *International Journal of Heat and Mass Transfer* 70 (2014) 641 – 650. doi:https://doi.org/10.1016/j. 740 ijheatmasstransfer.2013.11.037.
- [29] M. Cimmino, Fast calculation of the g-functions of geothermal borehole fields using similarities in the evaluation of the finite line source solution, *Journal of Building Performance Simulation* 11 (6) (2018) 655–668. doi:10.1080/19401493.2017.1423390.
- 745 [30] B. Leonard, A stable and accurate convective modelling procedure based on quadratic upstream interpolation, *Computer Methods in Applied Mechanics and Engineering* 19 (1) (1979) 59 – 98. doi:https://doi.org/10.1016/0045-7825(79)90034-3.
- [31] J. M. Ali, N. H. Hoang, M. A. Hussain, D. Dochain, Review and classifica- 750 tion of recent observers applied in chemical process systems, *Computers & Chemical Engineering* 76 (2015) 27–41.

- [32] C. V. Rao, J. B. Rawlings, D. Q. Mayne, Constrained state estimation for nonlinear discrete-time systems: Stability and moving horizon approximations, *IEEE transactions on automatic control* 48 (2) (2003) 246–258.
- 755 [33] P. Kühn, M. Diehl, T. Kraus, J. P. Schlöder, H. G. Bock, A real-time algorithm for moving horizon state and parameter estimation, *Computers & chemical engineering* 35 (1) (2011) 71–83.
- [34] Geothermische Screeningstool - SmartGeotherm, <http://tool.smartgeotherm.be/geo/alg>, accessed: 2018-09-06.
- 760 [35] G. Hellström, B. Sanner, Earth energy designer, User’s Manual, version 2 (2000).
- [36] J. Drgoňa, BeSim Toolbox: Fast Development, and Simulation of Advanced Building Control, <https://github.com/drgona/BeSim> (2019).
- 765 [37] J. Löfberg, YALMIP: a toolbox for modeling and optimization in MATLAB Proc, in: CACSD Conf.(Taipei)(<http://control.ee.ethz.ch/~joloef/yalmip.php>), 2004.
- [38] G. Optimization, Inc., “Gurobi optimizer reference manual,” 2015 (2015).
- 770 [39] G. Frison, J. Jorgensen, A fast condensing method for solution of linear-quadratic control problems, in: *Proceedings of 52nd IEEE Conference on Decision and Control*, 2013, pp. 7715–7720.